

INCIDENT: Water Contaminated at High School
LOCATION: Floyd County, Virginia
SOURCE:
DATE OF INCIDENT: 1/29/2009

A valve malfunction that contaminated water at Floyd County High School cancels classes. The contaminated water was restricted to one restroom and the kitchen. A pressure valve malfunctioned in the boiler system which transports heated water throughout the building. Due to the failure of the valve, fresh water was contaminated.