

INCIDENT: Poor Water Quality Call at a Meat Processing Plant
LOCATION: Guelph, Ontario
SOURCE:
DATE OF INCIDENT: Fall 2010

Operators found detergent in the water. Premises isolation was verified as functioning properly, testing was performed at a nearby fire hydrant. No contamination was found to be in the City water. The building once was compliant, but due to changes and additions to internal plumbing, locating the source of the contamination was unsuccessful. It was determined that it was an internal problem. Cooperation with the Operators and the City personnel stopped and the Operators resisted the City's help. After a couple hours it cleared up but the cause was never found.