



INSTITUTE OF  
CLEAN  
AIR  
COMPANIES

# **WHITE PAPER**

## **SELECTIVE NON-CATALYTIC REDUCTION (SNCR) FOR CONTROLLING NO<sub>x</sub> EMISSIONS**

**PREPARED BY:**

**SNCR COMMITTEE**

**INSTITUTE OF CLEAN AIR COMPANIES, INC.**

**February 2008**

*The Institute of Clean Air Companies (ICAC) is the national association of companies that supply stationary source air pollution monitoring and control systems, equipment, and services. It was formed in 1960 as a nonprofit corporation to promote the industry and encourage improvement of engineering and technical standards.*

*The Institute's mission is to assure a strong and workable air quality policy that promotes public health, environmental quality, and industrial progress. As the representative of the air pollution control industry, the Institute seeks to evaluate and respond to regulatory initiatives and establish technical standards to the benefit of all.*

|  | page |
|--|------|
| PURPOSE.....   | 4    |
| EXECUTIVE SUMMARY.....   | 4    |
| SELECTIVE NON-CATALYTIC REDUCTION (SNCR)<br>FOR CONTROLLING NO <sub>x</sub> EMISSIONS.....             | 4    |
| What is SNCR? .....  | 4    |
| How much NO <sub>x</sub> can SNCR remove? .....  | 5    |
| Is SNCR a new technology?.....   | 6    |
| Is SNCR commercially deployed?.....  | 6    |
| Are there applications for which SNCR is particularly<br>suited? .....                                 | 7    |
| How much does SNCR cost? .....   | 7    |
| What about ammonia slip? .....   | 8    |
| Does SNCR have other limitations?.....   | 8    |
| What are the common misconceptions regarding<br>SNCR? .....  | 8    |
| Can SNCR be used in combination with selective<br>catalytic reduction (SCR)? .....                     | 9    |
| How can SNCR be used to best advantage?.....   | 9    |
| What are the water quality considerations where<br>urea or aqueous ammonia is utilized for SNCR? ..... | 10   |
| APPENDIX 1: Selected Applications of Urea-Based SNCR,<br>by Industry .....                             | 11   |
| APPENDIX 2: Selected Applications of Ammonia-Based<br>SNCR, by Industry .....                          | 26   |
| REFERENCES .....   | 29   |

## PURPOSE

To comply with federal, state, and local acid rain and ozone non-attainment rules, both regulators and regulated industry seek nitrogen oxide ( $\text{NO}_x$ ) controls which offer the greatest reliability and effectiveness at the least cost. One such  $\text{NO}_x$  control technology is selective non-catalytic reduction (SNCR). Although SNCR will not be universally applicable, or always the most cost effective control strategy, in many cases it will meet the dual requirements of high performance and low cost, and so should be considered by affected sources and permitting authorities. To date, SNCR technology has been installed on 90 units in the power generation industry and on more than 300 industrial units (see Appendix 1 for a partial installation list).

The SNCR Committee of the Institute of Clean Air Companies, Inc. (ICAC) prepared this white paper to educate all interested parties on the capabilities, limitations, and cost of SNCR.

ICAC is the nonprofit national association of companies which supply stationary source air pollution monitoring and control systems, equipment, and services. Its members include suppliers of SNCR systems, and of competing  $\text{NO}_x$  control technologies.

## EXECUTIVE SUMMARY

Selective non-catalytic reduction (SNCR) is a chemical process for removing nitrogen oxides ( $\text{NO}_x$ ) from flue gas. In the SNCR process, a reagent, typically urea or anhydrous gaseous ammonia, is injected into the hot flue gas, and reacts with the  $\text{NO}_x$ , converting it to nitrogen gas and water vapor. No catalyst is required for this process. Instead, it is driven by the high temperatures normally found in combustion sources.

SNCR performance depends on factors specific to each source, including flue gas temperature, available residence time for the reagent and flue gas to mix and react, amount of reagent injected, reagent distribution, uncontrolled  $\text{NO}_x$  level, and  $\text{CO}$  and  $\text{O}_2$  concentrations. However, reductions in emissions of 25-75 % are common. Using appropriately designed SNCR systems, these levels of control are not accompanied by excessive emissions of unreacted ammonia (ammonia slip) or of other pollutants, particularly using recent design upgrades demonstrated on commercial systems. Further, SNCR does not generate any solid or liquid wastes.

SNCR also may be combined with low  $\text{NO}_x$  burners (LNB), over-fired air (OFA), neural networks, rich reagent injection (RRI), and selective catalytic reduction (SCR) systems or with gas reburn technologies to provide deeper emissions reductions for moderate capital investment. A combined SNCR/SCR system can be designed to use substantially less catalyst (typically installed "in-duct") than a conventional SCR, allowing

higher overall  $\text{NO}_x$  reduction than SNCR alone and lower ammonia slip, but with a relatively moderate increase in capital cost. A combined SNCR/SCR system can also be designed, particularly in the case of moderate duty boilers, to have a SNCR/SCR system to perform equivalently to a full SCR system to smoothen  $\text{NO}_x$  reduction at lower loads.

SNCR is a proven and reliable technology. SNCR was first applied commercially in 1974, and significant advances in understanding the chemistry of the SNCR process since then have led to improved  $\text{NO}_x$  removal capabilities as well as better ammonia slip control. As a result, approximately 400 SNCR systems have been installed worldwide. Applications include utility and industrial boilers, process heaters, municipal waste combustors, and other combustion sources.

SNCR is not a capital-intensive technology. Low capital costs, ranging from \$5-20/kWe on power generation units, make SNCR particularly suitable for use on lower capacity factor units, on units with short remaining service lives and for seasonal control. SNCR also is well suited for  $\text{NO}_x$  "trimming" and for use in combination with other  $\text{NO}_x$  reduction technologies. SNCR can provide 10-25 % reductions in power generation boiler  $\text{NO}_x$  emissions for total costs below 1 mill/kWh. Removal cost effectiveness values for SNCR center around \$1,500-2,500 per ton of  $\text{NO}_x$  removed.

The performance and cost of SNCR make this technology attractive for export, including to developing and former Soviet Union countries.

## SELECTIVE NON-CATALYTIC REDUCTION (SNCR) FOR CONTROLLING $\text{NO}_x$ EMISSIONS

### *What is SNCR?*

**Selective non-catalytic reduction (SNCR) is a chemical process that changes nitrogen oxides ( $\text{NO}_x$ ) into molecular nitrogen ( $\text{N}_2$ ), carbon dioxide ( $\text{CO}_2$ ) (if urea is used), and water vapor. A reducing agent, typically anhydrous gaseous ammonia or liquid urea, is injected into the combustion/process gases. At suitably high temperatures (1,600 - 2,100 F)<sup>1</sup>, the desired chemical reactions occur.**

Conceptually, the SNCR process is quite simple. A gaseous or aqueous reagent of a selected nitrogenous compound is injected into, and mixed with, the hot flue gas in the proper temperature range. The reagent then, without a catalyst, reacts with the  $\text{NO}_x$  in the gas stream, converting it to harmless nitrogen gas, carbon dioxide gas (if urea is injected), and water vapor. SNCR is "selective" in that the reagent reacts primarily with  $\text{NO}_x$ . A schematic depicting the SNCR process is shown in Figure 1.<sup>2</sup>






Figure 1. SNCR Process Schematic. Source: Fuel Tech

No solid or liquid wastes are created in the SNCR process.

While either urea or ammonia can be used as the reagent, for most commercial SNCR systems, urea has become the prevalent reagent used. Urea is injected as an aqueous solution while ammonia is typically injected in either its gaseous or anhydrous form using carrier air as a dilutive and support medium.

The principal components of the SNCR system are the reagent storage and injection system, which includes tanks, pumps, injectors, distribution modules, and associated controls. Given the simplicity of these components, installation of SNCR is easy relative to the installation of other  $\text{NO}_x$  control technologies. SNCR retrofits typically do not require extended source shutdowns.

### How much $\text{NO}_x$ can SNCR remove?

**While SNCR performance is specific to each unique application,  $\text{NO}_x$  reduction levels ranging from 30 % to more than 75 % have been reported.**

Temperature, residence time, reagent injection rate, reagent distribution in the flue gas, uncontrolled  $\text{NO}_x$  level, and  $\text{CO}$  and  $\text{O}_2$  concentrations are important in determining the effectiveness of SNCR.<sup>5</sup> In general, if  $\text{NO}_x$  and reagent are in contact at the proper temperature for a long enough time, then SNCR will be successful at reducing the  $\text{NO}_x$  level.

SNCR is most effective within a specified temperature range or window. A typical removal effectiveness curve, as a function of temperature within this window, is shown in Figure 2. At temperatures below the

window, reaction rates are extremely low, so that little or no  $\text{NO}_x$  reduction occurs. As the temperature within the window increases, the  $\text{NO}_x$  removal efficiency increases because reaction rates increase with temperature. Residence time typically is the limiting factor for  $\text{NO}_x$  reduction in this range. At the plateau, reaction rates are optimal for  $\text{NO}_x$  reduction. A temperature variation in this range will have only a small effect on  $\text{NO}_x$  reduction.




Figure 2. Typical SNCR Temperature Ranges

A further increase in temperature beyond the plateau decreases  $\text{NO}_x$  reduction. On the right side of the curve, the oxidation of reagent becomes a significant path and competes with the  $\text{NO}_x$  reduction reactions for the reagent. Although the efficiency is less than the optimum, operation on the right side is practiced and recommended to minimize byproduct emissions. On the left side of the curve, there is also greater potential for ammonia slip for a given  $\text{NO}_x$  removal and residence time.

The effective temperature window becomes wider as the residence time increases, thus improving the removal efficiency characteristics of the process. Long residence times ( $>0.3$  second) at optimum temperatures promote high  $\text{NO}_x$  reductions even with less than optimum mixing.

Normal stoichiometric ratio (NSR) is the term used to describe the  $\text{N}/\text{NO}$  molar ratio of the reagent injected to the uncontrolled  $\text{NO}_x$  concentrations. In general, one mole of ammonia species will react with one mole of  $\text{NO}$  in the reduction reaction. If one mole of anhydrous ammonia is injected for each mole of  $\text{NO}_x$  in the flue gas, the NSR is one, as one mole of ammonia will react with one mole of  $\text{NO}_x$ . If one mole of urea is injected into the flue gas for each mole of  $\text{NO}_x$ , the NSR is two. This is because one mole of urea contains two ammonia radicals and will react with two moles of  $\text{NO}_x$ .<sup>5</sup> For both reagents, the higher the NSR, the greater the  $\text{NO}_x$  reduction. Increasing NSR beyond a certain point, however, will have a diminishing effect

on NO<sub>x</sub> reduction with a resultant increase in ammonia slip and reagent cost.

### *Is SNCR a new technology?*

**No. Commercial installations using SNCR have been in existence for more than 30 years.**

The first commercial application of SNCR was in Japan in 1974.<sup>4</sup> This installation used anhydrous ammonia. At about the same time, the anhydrous ammonia injection process was patented in the U.S. by Exxon Research and Engineering Co. This process is commonly known as the Thermal DeNO<sub>x</sub> process.

Fundamental thermodynamic and kinetic studies of the NO<sub>x</sub>-urea reaction occurred during 1976-1981 under the direction of the Electric Power Research Institute (EPRI). Patents granted to EPRI for this process were licensed to Fuel Tech which, with its implementors and sub-licensees, has marketed the urea-based NOxOUT<sup>®</sup> process with improvements to the original patents.

### *Is SNCR commercially deployed?*

**SNCR systems are in commercial operation in the United States, as well as in Europe and Asia and is one of the key technologies used for compliance with the NO<sub>x</sub> SIP Call program.**

SNCR is a fully commercial NO<sub>x</sub> reduction technology, with successful application of the urea- and ammonia-based processes at approximately 400 installations worldwide (see Appendix 1 and 2), covering a wide array of stationary combustion units firing an equally diverse types of fuels.

In the U.S., commercial installations or full-scale demonstrations include virtually every boiler configuration and fuel type, as well as other major NO<sub>x</sub> emitting process units, such as cement kilns and incinerators. Urea-based SNCR has been applied commercially to sources ranging in size from a 60 MMBtu/hr (gross heat input) paper mill sludge incinerator to a 640 MWe pulverized coal-fueled, wall-fired electric utility boiler. The earliest commercial urea-based SNCR system in the U.S. was installed in early 1988 on a 614 MMBtu/hr CO boiler in a Southern California oil refinery. This SNCR system reduces NO<sub>x</sub> emissions 65 % from a baseline of 90 ppm.

Industrial boilers, process units, municipal and hazardous waste combustors, and power boilers make up the largest share of commercial SNCR installations in the U.S. This distribution is determined more by NO<sub>x</sub> control regulations than by SNCR process limitations. To illustrate the breadth of deployment of SNCR, the following examples of commercial installations include:

- Two 500 MWe cyclone-fired boilers at Ameren utilize a combination of SNCR with RRI<sup>®</sup>, which is an offshoot of SNCR technology under license with EPRI.

- Two 75 MWe pulverized coal tangentially fired power boilers in California equipped with low NO<sub>x</sub> burners and overfire air required the installation of SNCR to meet a 165 ppm permit limit.<sup>5</sup>
- SNCR systems installed on the coal-burning, wall-fired Dominion Energy's Salem Harbor Station Units 1, 2 (84 MWe each) and 3 (156 MWe) in 1993, together with LNBs, can reduce NO<sub>x</sub> emissions 50-75 % from a baseline of 0.85-1.12 lb/MMBtu.
- Commercial SNCR systems retrofit on 320 MWe wet-bottom, twin furnace boilers in New Jersey provide 30-35 % NO<sub>x</sub> reductions.<sup>6</sup>
- Commercial SNCR systems retrofit on cyclone-fired boilers in New Jersey reduce NO<sub>x</sub> emissions by 35-40 %.
- SNCR is achieving compliance with RACT limits at coal-fired boilers in Massachusetts<sup>7</sup> and Delaware.<sup>8</sup>
- A SNCR system installed on a 640MW supercritical boiler is achieving 25 % removal efficiency using only wall injectors. This option offers lower cost (about \$6/KW including installation) than utilizing multi-nozzle lances.
- SNCR systems at Duke Energy's Marshall Station on 600 MWe boilers incrementally reduced NO<sub>x</sub> by 25 % above the reductions being obtained with LNB.
- An SNCR system installed on a circulating fluidized bed boiler designed to produce 350,000 lb/hr of steam can reduce NO<sub>x</sub> emissions from a baseline of 0.2-0.35 lb/MMBtu to below 0.15 lb/MMBtu over a load range of 40-100 %.<sup>9</sup>
- Among significant applications in the U.S.:
- A SNCR system on a 600 MW coal-fired boiler firing 3.5 % sulfur coal reduced NO<sub>x</sub> by 30 % across the load range while maintaining ammonia slip near 5 ppm. The unit experienced very few operational difficulties.<sup>10</sup>
- SNCR, in conjunction with combustion tempering, is achieving NO<sub>x</sub> reductions of nearly 60 % on a 244 MWe gas-fueled cyclone boiler.<sup>11</sup>
- SNCR, in conjunction with burner optimizations, reduced NO<sub>x</sub> on coal over 70 % on coal fired boilers.<sup>12</sup>
- SNCR provided an 80+ % reduction from uncontrolled emissions of 3.5-6.0 lb NO<sub>x</sub> per ton of clinker in a demonstration at a West Coast cement kiln.
- A SNCR system in combination with a modified reburn process is meeting 0.2 lb/MMBtu on a 600 MW boiler firing Powder River Basin coal.

SNCR also has been commercially installed and demonstrated in Asia. For example, an SNCR system installed on a 331 MMBtu/hr pulverized coal-fired industrial boiler in Kaohsiung, Taiwan, in 1992 reduced

NO<sub>x</sub> emissions from this front-fired boiler from 300 to 120 ppm.

In addition, SNCR has been commercially installed throughout Europe. Installations include coal-fueled district heating plant boilers, electric utility boilers, municipal waste incinerators, and many package boilers.

In Germany, commercial SNCR systems installed on municipal waste incinerators in Hamm, Herten, and Frankfurt reduce NO<sub>x</sub> emissions 40-75 % from base-lines of 160-185 ppm. SNCR also has been installed on more than 20 heavy oil-fired Standardkessel package boilers.

In Sweden, a commercial SNCR system on a 275 MMBtu/hr coal-fueled, stoker-fired boiler at the Linköping P1 district heating plant reduces NO<sub>x</sub> emissions 65 % from a baseline of 300-350 ppm. At the Nyköping demonstration on a 135 MMBtu/hr coal-fueled circulating fluidized-bed boiler, SNCR achieves a 70 % NO<sub>x</sub> reduction from a 120-130 ppm baseline. Demonstrations of SNCR, in addition to municipal waste incinerators and wood- and coal-fueled district heating plant boilers, included a pulp and paper mill kraft recovery boiler, where a 60 % reduction from uncontrolled emissions of 60 ppm was attained.<sup>15</sup>

To meet new environmental demands in Eastern Europe, SNCR systems were installed on five coal-fired industrial boilers in the Czech Republic since 1992.

### ***Are there applications for which SNCR is particularly suited?***

**Yes. Some applications have combinations of temperature, residence time, unit geometry, and uncontrolled NO<sub>x</sub> level, and operating modes which make them especially well-suited for cost-effective reduction of NO<sub>x</sub> by SNCR.**

Certain applications are technically well-suited for the use of SNCR. These include combustion sources with exit temperatures in the 1550-1950 °F range and residence times of one second or more, examples of which are many municipal waste combustors, sludge incinerators, CO boilers, and circulating fluidized bed boilers. Furnaces or boilers with high NO<sub>x</sub> levels or which are not suited to combustion controls, e.g., cyclone-type or other wet bottom boilers and stokers and grate-fired systems, also are good candidates for SNCR.

Other applications are well-suited to the use of SNCR for economic reasons. For these applications, controls with reduced capital cost, even at the expense of somewhat higher operating costs, may be the least expensive to operate. Applications meeting these criteria include units with lower capacity factors, such as peaking and cycling boilers, units requiring limited control, e.g., additional “trim” beyond combustion control or seasonal control.

### ***How much does SNCR cost?***

**The capital cost of a selective non-catalytic reduction system is among the lowest of all NO<sub>x</sub> re-**

**duction methods. Recent innovations in the control of reagent injection make SNCR operating costs amongst the lowest of all NO<sub>x</sub> reduction methods.**

SNCR is an operating expense-driven technology, so that the absolute cost of applying SNCR varies directly with the NO<sub>x</sub> reduction requirements.

Typical SNCR capital costs for utility applications are \$5-15/kW, vendor scope, which corresponds to a maximum of \$20/kW if balance-of-plant capital requirements are included. For example, the total capital requirement for the commercial installation of SNCR at New England Electric's Salem Harbor Station (three pulverized coal-fired boilers) was \$15/kW.<sup>14</sup> Similarly, total capital requirements for Public Service Electric and Gas' Mercer Station Unit 2 and B.L. England Station Unit 1 were \$10.6/kW and \$15/kW, respectively.<sup>15</sup> Southern California Edison reported an even lower capital requirement of \$3/kW for installing “urea injection” on 20 units totaling 5600 MW<sup>16</sup>.

On an updated turn-key basis, a typical SNCR would range from \$1325-7000/MMBtu/hr depending on the process category. An example of a high cost application, might apply to an all-in cost for an extremely small rotary kiln. On the opposite end, the lower cost applications are typically large hazardous waste incinerators and large bubbling bed/fluidized bed boilers and large wood-fired stokers.

For similar type sources, the installed capital cost per unit of output (e.g., \$/kWe) decreases as the source size increases, i.e., due to economy of scale, total capital outlay increases less than linearly with increasing boiler capacity.

Given such low capital requirements, most of the cost of using SNCR will be operating expense. A typical breakdown of annual costs for utilities will be 25 % for capital recovery and 75 % for operating expense. For industrial sources, annual costs will be 15-35 % for capital recovery and 65-85 % for operating expense. For an operating expense-driven technology, little cost will be incurred if the source is not operating, and cost effectiveness (the cost per ton of NO<sub>x</sub> removed) will be relatively insensitive to capacity factor or duty cycle. This makes SNCR particularly attractive for seasonal control of NO<sub>x</sub> emissions. (For capital-intensive technologies, cost effectiveness becomes worse with decreasing capacity factor.)

Demonstrated cost-effectiveness values for SNCR are low, ranging from \$400 to \$3,000 per ton of NO<sub>x</sub> removed, depending upon site-specific factors. For example, the cost effectiveness of SNCR at Dominion Energy's Salem Harbor Station unit 2 is \$670/ton.<sup>17</sup> The wide range exists because of differing conditions found across different facilities, even within the same industry. For utility boilers alone, cost effectiveness varies with factors such as uncontrolled NO<sub>x</sub> level, required emission reduction, unit size, capacity factor (or duty cycle), heat rate (or thermal efficiency), degree of retrofit difficulty, and economic life of the unit.



Of primary interest to electric utilities is the cost of pollution controls per unit of electricity generated, expressed on a busbar basis (mills/kWh). For SNCR, the busbar cost varies directly with the amount of  $\text{NO}_x$  to be removed. Costs range from less than 1.0 mill/kWh for “trim reduction” on a coal-fired unit or RACT-level reduction on an oil-fired unit, to 3.5 mills/kWh for a 75 % reduction on a unit with uncontrolled emissions greater than 1 lb  $\text{NO}_x$ /MMBtu. A commercial installation of urea-based SNCR on a Dominion Energy’s unit has a busbar cost of 2.7 mills/kWh, and a cost effectiveness of approximately \$1,000/ton. (To convert the busbar costs of SNCR to a cost increment relative to fuel price, 0.5–3.5 mills/kWh is roughly equivalent to \$0.05–\$0.35/MMBtu.)

Innovations in SNCR control systems and continued system optimization during operation have reduced reagent usage at commercial installations, thus decreasing operating costs further. At one coal-fired utility boiler, a control upgrade, including continuous ammonia and temperature monitors, improved control hardware and software, and additional injector pressure controls, allow over a 50 % decrease in reagent use from baseline levels.<sup>18</sup> At a second coal- and oil-fired unit, system optimization after start-up has lowered reagent consumption 35 % below predicted levels.<sup>19</sup> Given that the reagent dominates SNCR operating cost, such large reductions in reagent use translate to significant reductions in operating cost.

### *What about ammonia slip?*

**Ammonia slip, or emissions of ammonia which result from incomplete reaction of the  $\text{NO}_x$  reducing reagent, typically can be limited to low levels.**

Ammonia slip may result in one or more problems, including:

- Formation of ammonium bisulfate or other ammonium salts which can plug or corrode the air heater and other downstream components;
- Ammonia absorption on fly ash, which may make disposal or reuse of the ash difficult;
- Formation of a white ammonium chloride plume above the stack; and,
- Detection of an ammonia odor around the plant.

Ammonia slip is controlled by careful injection of reagent into regions of the furnace or other sources where proper conditions (temperature, residence time, and  $\text{NO}_x$  concentration) for the SNCR reaction exist. If the reagent reacts in a region where the temperature is too low for the  $\text{NO}_x$ -reducing reaction to occur in the available residence time, then some unreacted ammonia will be emitted. Further, if reagent is injected in such a way that some regions of the furnace are over treated, the excess reagent can lead to ammonia slip. Thus, it is critical that the SNCR injection system be designed to provide the appropriate reagent distribution.

The difficulty in controlling ammonia slip will vary from application to application. At many commercial installations, particularly in electric utilities, units have operated with ammonia slip levels of equal to or less than 5 ppm upstream of the air heater to meet the requirements of owners or permitting authorities. This is a far more stringent criterion than stack emissions. In any case, ammonia concentrations at ground level will be well below thresholds for both odor and toxicity.

Control system upgrades and process optimization after installation can lower slip below guaranteed levels. Thus, at a commercial SNCR system on a coal-fired boiler, improved controls have lowered ammonia slip from 10–15 ppm to below 5 ppm, and have reduced ammonia on the fly-ash by half.

Use of a down-sized SCR downstream of a SNCR also optimizes the integration to ammonia-sensitive units.

### *Does SNCR have other limitations?*

**As do all pollution control technologies, SNCR has limitations which must be understood in order to use it properly to optimize the control of  $\text{NO}_x$  emissions.**

**High temperature and critical  $\text{NO}_x$  concentration.** As temperature increases, the “critical” or equilibrium  $\text{NO}_x$  concentration at a given oxygen concentration increases. At high enough temperatures, any reduction of  $\text{NO}_x$  to below the critical level by SNCR or other means will be counteracted by the rapid oxidation of nitrogen to re-form  $\text{NO}_x$ . For this reason, at sufficiently high temperatures and baseline  $\text{NO}_x$  levels below the critical concentration, injection of ammonia or urea into the flue gas will result in *increased*  $\text{NO}_x$  levels. If, however, the baseline  $\text{NO}_x$  concentration is above the critical level,  $\text{NO}_x$  reduction will result. For typical coal- and oil-fired steam boilers, critical  $\text{NO}_x$  levels are 70–90 ppm (ca. 0.1 lb/MMBtu) in the upper furnace.

**High furnace carbon monoxide concentration.** High CO concentrations can shift the temperature window of the SNCR process. When CO concentrations in the region of reagent injection are above 300 ppm, the critical  $\text{NO}_x$  level and SNCR reaction rate will increase above what they would have been had little CO been present, as if the temperature were slightly higher. Therefore, in some furnaces with high CO levels, it is preferable to inject reagent at lower temperatures to effect good  $\text{NO}_x$  control.

**Carbon monoxide emissions.** In a well-controlled urea-based SNCR system, the carbon contained in the urea is fully oxidized to carbon dioxide. Normally, steps taken to control ammonia slip impose sufficient restrictions on reaction temperature to prevent substantial emissions of CO.

### *What are common misconceptions regarding SNCR?*

**In earlier days, several common misconceptions initially slowed the acceptance of SNCR by utilities.**

**Misconception: As boiler size increases, SNCR efficiency decreases.** As long as reagent can be distributed, there is no technical limitation to the size of boilers on which SNCR will be effective. This misconception arose in part from the earliest experiences at large utility boilers in California. These boilers were equipped with low NO<sub>x</sub> combustion systems, had high furnace exit gas temperatures, and very rapid cooling of the gases in the boiler convective regions. Low baseline NO<sub>x</sub> levels resulting from these natural gas-fired boilers and rapid cooling led to low NO<sub>x</sub> control efficiencies and high ammonia slips using SNCR. Increased technical knowledge and experience have allowed better delineation of the limitations of the SNCR process, which since then has been used to achieve over 60 % NO<sub>x</sub> reductions on some electric utility boilers.

The commercial development of retractable multi-nozzle lances as well as advances in feed-forward controls has extended the applicability of urea-based SNCR technology. These advances enable delivery of reagent across the boiler, as has been demonstrated both in the U.S. and abroad. Today, there are several facilities utilizing SNCR on units of greater than 600 MW capacity.

**Misconception: SNCR cannot be used on boilers equipped with low NO<sub>x</sub> combustion controls.** SNCR has been installed commercially on boilers equipped with low NO<sub>x</sub> burners, overfire air, and flue gas recirculation, and has been shown to operate effectively with all of these technologies.<sup>20</sup> Typically, SNCR reduces NO<sub>x</sub> an additional 20-30 % above LNB/combustion modifications.

**Misconception: Use of SNCR on coal-fired plants results in fly ash which cannot be sold and the disposal of which is expensive.** The tendency of fly ash to absorb ammonia is a function of many factors in addition to the amount of ammonia slip. Ash characteristics such as pH, alkali mineral content, and volatile sulfur and chlorine content help to determine whether or not ammonia will be absorbed readily by the fly ash. In most applications, properly designed SNCR systems will keep the ammonia slip levels low enough so that the salability of the ash should be unaffected.

### ***Can SNCR be used in combination with selective catalytic reduction (SCR)?***

**Hybrid SNCR-SCR systems have been demonstrated at a number of utility plants, and are being commercially installed to meet post-RACT NO<sub>x</sub> limits.**

SNCR may be combined with selective catalytic reduction (SCR) using a number of different techniques. NO<sub>x</sub> control with an SNCR system alone is often limited by ammonia slip requirements. One commercially available hybrid SNCR-SCR system design generates ammonia slip intentionally as the reagent feed to the SCR catalyst, which provides additional NO<sub>x</sub> removal. The quantity of catalyst required in a hybrid system can be reduced from that of an SCR-only application,

so that the hybrid system could have lower capital requirements.

At two gas-fired utility boilers in Southern California, hybrid systems gave emissions reductions of 72-91 percent.<sup>21</sup> At a wet bottom coal-fired boiler in New Jersey, a hybrid system reduced NO<sub>x</sub> emissions by up to 98 percent. In a DOE Clean Coal Technology installation, the combination of SNCR with smaller SCR will reduce NO<sub>x</sub> below 0.15 lb/mmBtu at less than two-thirds the cost of full SCR.<sup>22</sup> This hybrid approach has been demonstrated in several full-scale utility applications and as a result of the installation at AES Greenidge has been commercially applied. SNCR can also be applied to units with a conventional SCR system with a standard ammonia injection grid.

### ***How can SNCR be used to best advantage?***

**The features of being a low hazard, low capital cost, expense-driven technology that requires little space and little unit down-time to implement suggests various appropriate uses to comply with U.S. clean air regulations.**

#### **Beyond-RACT Controls for Ozone Attainment.**

States not meeting the ozone National Ambient Air Quality Standard after application of RACT controls will require greater NO<sub>x</sub> reductions from sources within their borders. Many states presume that these reductions will be based on the addition of post-combustion controls, including SNCR. In some cases, SNCR could be retrofit to units that already have implemented combustion modifications. Where SNCR has been used to meet RACT limits, the reagent use rate could be increased to meet new, lower limits.

**Seasonal Controls for Ozone Attainment.** In a seasonal approach, NO<sub>x</sub> reductions beyond RACT would be required only during the "ozone season" (May through September) when exceedances normally occur. For example, the states of the northeast Ozone Transport Region have committed to a plan calling for control of ozone precursors only during the May-September ozone season to help meet regional ozone attainment goals. SNCR is particularly well-suited for seasonal control in that it may provide deep reductions in NO<sub>x</sub> emissions, but incurs little cost when the system is not in use. For urea-based SNCR, the incremental cost of control during the ozone season would be on the order of \$0.30/MMBtu on a unit without low-NO<sub>x</sub> burners, expressed as a fuel cost adder relative to the "off" season.

**Acid Rain Control.** Under the acid rain provisions (Title IV) of the Clean Air Act Amendments, NO<sub>x</sub> limits for Group 2 coal-fired utility boilers, which include cyclones, wet-bottom wall-fired boilers, cell-burner-fired boilers, stoker-fired units, and roof-fired boilers were promulgated in 1996 based upon the capabilities and costs of available control technologies.

SNCR technology has been successfully installed on cell-, pulverized-coal wet bottom-, cyclone-, and stoker-fired units as well as on circulating fluidized bed boilers.

**Overcontrol.** The low capital cost and ease of retrofit of SNCR suggest its use as an add-on to other NO<sub>x</sub> control technologies to provide overcontrol, or control to below permit limits. Overcontrol can be useful where the marginal cost of control on one unit is lower than on other units, and where averaging or trading emissions or emissions reductions is permitted. Trading provisions of the proposed NO<sub>x</sub> SIP Call regulation, the Regional Clean Air Incentives Market (RECLAIM) instituted by the California South Coast Air Quality Management District, the acid rain NO<sub>x</sub> rule, and proposed rules for generation of emissions reduction credits all authorize strategies based on overcontrol.

In an overcontrol strategy, a second SNCR system may be used to provide insurance: If the overcontrolled unit in the averaged group is forced out of service, the insurance system is available to provide the requisite emissions reductions on a second unit. When the overcontrolled unit is in service, the cost of the insurance SNCR system is limited to a relatively low capital charge.

**BACT/New Source Controls.** SNCR has been utilized to fulfill best achievable control technology (BACT) requirements for new stoker units in Maine, Vermont, Massachusetts, Connecticut, and Virginia, among other states. In North Carolina, a new pulverized coal-fired unit was permitted recently with SNCR to meet a 0.17 lb/MMBtu NO<sub>x</sub> emission limit.

### ***What are the water quality considerations where urea or aqueous ammonia is utilized for SNCR?***

Water quality and product handling are important components of the overall successful operation of the emissions control system when urea or aqueous ammonia reagents are used in post-combustion applications. Water quality is important in order to minimize system fouling and corrosion that can result in reduced SNCR system on-line time, higher maintenance costs, and the inability to meet emissions targets. Proper product handling and storage equipment is necessary in order to assure that the quality of the reagents have the optimum characteristics for industrial emissions control applications.

With urea-based SNCR systems, urea is generally shipped as a 50 percent solution but is also available and shipped from a range of concentrations from 32 percent to 70 percent solution. Depending on the urea manufacturer, the water used to ship urea may be demineralized for quality purposes. Prior to injection, urea solution is diluted in-line anywhere from 50 percent to 80 percent. Water quality for this dilution step is important to the success of the application because urea (as well as ammonia) is highly alkaline in water and will precipitate hardness and other minerals. Demineralized water will remove any potential sus-

pended solids which may lead to plugging of injection lances and other components of the SNCR system. The dilution water for SNCR remains stable if: (1) urea is purchased from suppliers who supply "NO<sub>x</sub> grade urea liquor" whereby stabilizers have been mixed into the solution, or (2) otherwise the dilution water should be of high quality which can be achieved through demineralization or reverse osmosis type processes in order to provide maximum insurance. Table 1 provides a range of physical properties for varying concentrations of urea liquor seen in typical SNCR applications.

**Table 1. Range of Properties for SNCR Grade Urea Liquor from Demineralized Water**

| <i>Characteristic</i>             | <i>Range</i>     |
|-----------------------------------|------------------|
| Urea Concentration                | 32 to 70         |
| Free Ammonia (at loading)         | <0.2% to <0.5 %  |
| Biuret (at loading)               | <0.5 % to <0.7 % |
| Magnesium (Mg) ppm                | <0.5 to <0.8     |
| Calcium (Ca) ppm                  | <0.5 to <0.8     |
| Phosphates as PO <sub>4</sub> ppm | <0.5 to <1.5     |
| Iron (Fe) ppm                     | <0.5 to <0.8     |

Urea supply chain and storage is important in order to provide the quality assurance and quality control of the urea liquor used for SNCR systems. The vast majority of anhydrous ammonia and urea manufactured in North America is produced for agricultural purposes where water quality in the make-up/dilution water is less of an issue. For anhydrous ammonia and urea that is produced domestically, between 85-90 percent is used for fertilizer. Agricultural applications place a higher priority on the nitrogen value and certain physical characteristics of the urea to ensure that the fertilizer is evenly distributed when fertilizing fields. Urea and anhydrous ammonia that is produced for SNCR grade applications has a higher standard for the quality of the water used for the make-up/dilution processes. Although supply is available in most locations in North America, the actual distance between point of production and final use can add up to tens of thousands of miles of transport by road, rail, ship, and pipeline involving material handling at each step of the delivery process. Some manufacturers have dedicated supply and storage systems for SNCR grade urea and anhydrous ammonia in order to ensure that this is no contamination between agricultural and industrial grade products. Although not mandatory, minimizing the risk of contamination of the urea or anhydrous ammonia during the supply chain will ensure that the supply of reagent meets the tight quality control requirements demanded in the air emissions control systems.



| COMPANY / LOCATION   | UNIT TYPE                                     | SIZE<br>(MMBtu/hr)                   | FUEL                         | NO <sub>x</sub> BASELINE<br>(ppm)                                | REDUCTION<br>%           |
|--|---|--------------------------------------|------------------------------|--|--------------------------|
| <b>Utility Boilers</b>   |   |                                      |                              |  |                          |
| American Electric Power<br>Cardinal Station Unit #1<br>Brilliant, OH         | B & W<br>Universal Press.                     | 5347<br>(600 MW)                     | Coal                         | 0.57 lb/MMBtu  | 30                       |
| AEP - Southwestern Electric Power<br>Pirkey Station Unit 1<br>Hallsville, TX | B&W<br>Opposed Wall<br>Fired                  | 6900<br>(710 MW)                     | Coal                         | 0.19 lb/MMBtu  | 20                       |
| Dynegy<br>Danskammer Unit 4  | CE<br>T-Fired                                 | 240 MW                               | Coal                         | 0.25 lb/MMBtu  | 20                       |
| Reliant Energy<br>Shawville Unit 2   | B&W<br>Wall Fired                             | 133 MW                               | Coal                         | 0.5 lb/MMBtu   | 25                       |
| Alabama Power<br>Gaston Station Unit 3<br>Wilsonville, AL                    | B&W<br>Opposed Wall<br>Fired                  | 2474<br>(250 MW)                     | Coal                         | 0.44 lb/MMBtu  | 25                       |
| Ameren<br>Sioux Station Unit 1   | Cyclone                                       | 510 MW                               | PRB Coal                     | 0.25 lb/MMBtu  | 50                       |
| AES/Indianapolis Power and Light<br>Harding Street Station<br>Units 5 and 6  | C.E. T-Fired                                  | 110 MWg each                         | Coal                         | 0.36 lb/MMBtu  | 30-40                    |
| Alabama Power<br>Barry Units 1-4<br>Bucks, AL                                | T-Fired<br>T-Fired<br>Twin Furnace<br>T-Fired | 153 MW<br>153 MW<br>272 MW<br>400 MW | Coal<br>Coal<br>Coal<br>Coal | 0.49 lb/MMBtu<br>0.46 lb/MMBtu<br>0.40 lb/MMBtu<br>0.29 lb/MMBtu | 27.5<br>27.5<br>25<br>25 |
| Atlantic Electric<br>B.L. England Station (3 units)<br>Mays Landing, NJ      | Cyclone<br>Cyclone<br>T-Fired                 | 138 MW<br>160 MW<br>160 MW           | Coal<br>Coal<br>#6 Oil       | 1.31 lb/MMBtu<br>1.40 lb/MMBtu<br>0.31 lb/MMBtu                  | 31.3<br>36<br>35         |
| Austrian Energy<br>Vojany Power Station<br>Slovak Republic                   | Utility                                       | 1146                                 | Pulverized Coal              | 789 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub><br>1.58 *         | 32                       |
| Cinergy Miami Fort Unit #6<br>Northbend, OH                                  | Tangential Fired<br>C.E.                      | 1490                                 | Coal                         | 0.55 lb/MMBtu  | 35                       |
| Delmarva Power<br>Wilmington, DE   | T-fired                                       | 84 MWe                               | Coal                         | 0.54 lb/MMBtu  | 30                       |
| Dominion Generation<br>Clover Station, Units 1 & 2<br>Clover, VA             | CE T-Fired                                    | 465 MW each                          | Coal                         | 0.32 MMBtu   | 25                       |
| Dominion/NEPCO Unit 1<br>Salem Harbor, MA                                    | Front-Fired                                   | 84 MW                                | Coal                         | 1.00 ± 0.10 *  | ~ 66 **                  |
| Dominion/NEPCO Unit 2<br>Salem Harbor, MA                                    | Front-Fired                                   | 84 MW                                | Coal                         | 1.00 ± 0.10 *  | ~ 66 **                  |
| Dominion/NEPCO Unit 3<br>Salem Harbor, MA                                    | Front-Fired                                   | 156 MW                               | Coal                         | 1.00 ± 0.10 *  | ~ 66 **                  |

| COMPANY / LOCATION   | UNIT TYPE                 | SIZE<br>(MMBtu/hr) | FUEL | NO <sub>x</sub> BASELINE<br>(ppm) | REDUCTION<br>% |
|--|---------------------------|--------------------|------|-----------------------------------|----------------|
| Duke Energy<br>Allen Station Unit 1<br>Belmont, NC                             | CE T-Fired                | 1751<br>(185 MW)   | Coal | 0.22 lb/MMBtu                     | 25             |
| Duke Energy Allen Station Unit<br>2 Belmont, NC                                | CE T-Fired                | 1751 (185 MW)      | Coal | 0.22 lb/MMBtu                     | TBD            |
| Duke Energy<br>Allen Station Unit 3<br>Belmont, NC                             | CE Twin Furnace           | 2546<br>(270 MW)   | Coal | 0.22 lb/MMBtu                     | 23             |
| Duke Energy<br>Allen Units 4 & 5<br>Belmont, NC                                | CE Twin Furnace           | 2546<br>(270 MW)   | Coal | 0.22 lb/MMBtu                     | 23             |
| Duke Energy<br>Buck Station Units 5 & 6<br>Salisbury, NC                       | CE T-Fired                | 1230<br>(142 MW)   | Coal | 0.20 lb/MMBtu                     | 20             |
| Duke Energy<br>Marshall Station Unit 3<br>Terrell, NC                          | CE 8-Corner               | 6130<br>(660 MW)   | Coal | 0.267 lb/MMBtu                    | 20             |
| Duke Energy<br>Marshall Station Units 1 & 2<br>Terrell, NC                     | CE 8-Corner               | 3367<br>(350 MW)   | Coal | 0.245 lb/MMBtu                    | 20             |
| Duke Energy<br>Riverbend Station Units 4 & 5<br>Salisbury, NC                  | CE T-Fired                | 937<br>(100 MW)    | Coal | 0.25 lb/MMBtu                     | TBD            |
| Duke Energy<br>Riverbend Station Units 6 & 7<br>Salisbury, NC                  | CE T-Fired                | 1318<br>(133 MW)   | Coal | 0.20 lb/MMBtu                     | TBD            |
| Exelon Philadelphia Electric Co.<br>Cromby Station, Unit 1<br>Phoenixville, PA | B&W<br>Divided Furnace    | 1480               | Coal | 0.50 lb/MMBtu                     | 25             |
| Exelon<br>Eddystone Station Units 1-2<br>Eddystone, PA                         | T-Fired<br>Twin Furnace   | 318 MWg<br>333 MWg | Coal | 0.26 lb/MMBtu                     | ~ 30%          |
| First Energy<br>East Lake Unit 3<br>East Lake, OH                              | CE 8-Corner               | 1470<br>(120 MW)   | Coal | 0.34-0.40<br>lb/MMBtu             | 20 - 32.5      |
| First Energy<br>East Lake Unit 5<br>East Lake, OH                              | B & W<br>Universal Press. | 620 MWg            | Coal | 0.38 lb/MMBtu                     | 25             |
| First Energy<br>Sammis Unit 1<br>Sammis, OH                                    | FW Front Wall<br>Fired    | 180 MW             | Coal | 0.38 lb/MMBtu                     | 25             |
| First Energy<br>Sammis Unit 2<br>Sammis, OH                                    | FW Front Wall<br>Fired    | 180 MW             | Coal | 0.38 lb/MMBtu                     | 25             |



| COMPANY / LOCATION   | UNIT TYPE                      | SIZE<br>(MMBtu/hr) | FUEL                | NO <sub>x</sub> BASELINE<br>(ppm) | REDUCTION<br>% |
|--|--------------------------------|--------------------|---------------------|-----------------------------------|----------------|
| First Energy<br>Sammis Unit 3<br>Sammis, OH                                    | FW Front Wall<br>Fired         | 180 MW             | Coal                | 0.38 lb/MMBtu                     | 25             |
| First Energy<br>Sammis Unit 4<br>Sammis, OH                                    | FW Front Wall<br>Fired         | 180 MW             | Coal                | 0.38 lb/MMBtu                     | 25             |
| First Energy<br>Sammis Unit 5<br>Sammis, OH                                    | B&W Wall Fired                 | 300 MW             | Coal                | 0.45 lb/MMBtu                     | 25             |
| First Energy<br>Sammis Unit 6<br>Sammis, OH                                    | B & W<br>Universal Press.      | 620 MWg            | Coal                | 0.38 lb/MMBtu                     | 25             |
| First Energy<br>Sammis Unit 7<br>Sammis, OH                                    | B & W<br>Universal Press.      | 620 MWg            | Coal                | 0.38 lb/MMBtu                     | 25             |
| Gulf Power Company<br>Crist, Unit 6<br>Pensacola, FL                           | FWEC                           | 320 MW             | Coal                | 0.35 lb/MMBtu                     | ~ 30           |
| Korean Electric Power Co.<br>Honam Station, Units 1 & 2<br>Korea               | Front & Rear<br>Wall-Fired     | 2474               | Coal                | 0.654 lb/MMBtu                    | 40             |
| Northeast Utilities<br>Schiller Station Units 4, 5 & 6<br>Portsmouth, NH       | Foster Wheeler<br>Front Fired  | 50 MW each         | Coal                | 0.45 lb/MMBtu                     | 50             |
| NRG/Eastern Utilities<br>Somerset, MA  | Tilting T-Fired<br>Boiler      | 410-1120           | Coal, Oil           | 0.49 – 0.89<br>lb/MMBtu           | 28 – 60        |
| NRG/Northeast Utilities<br>Middletown Unit 3<br>Middletown, CT                 | Cyclone-Fired                  | 2455 MMBtu/hr      | Gas                 | 0.34 lb/MMBtu                     | 25             |
| NRG/Northeast Utilities<br>Norwalk Harbor Station, Units 1&2<br>S. Norwalk, CT | CE Twin T-Fired                | 172 MWg<br>182 MWg | Oil                 | < 0.40 *                          | < 0.25         |
| Pennsylvania Electric Company<br>Comby Station                                 | B&W Divided<br>Furnace         | 1480               | Coal                | 0.5 lb/MMBtu                      | 25             |
| PSE&G<br>Hudson Station, Unit #2<br>Jersey City, NJ                            | Foster Wheeler<br>Opposed Wall | 660 MWg            | Coal<br>Natural Gas | 0.65 lb/MMBtu<br>0.35 lb/MMBtu    | 25<br>25       |
| Reliant Energy/Penelec<br>Seward Unit 15                                       | CE-T-Fired                     | 1457 MMBtu/hr      | Coal                | 0.78 lb/MMBtu                     | 35             |
| Rochester Gas & Electric<br>Russell Station, Units 1-4                         | CE T-Fired                     | 265 MW Total       | Coal                | 0.28 - 0.42<br>lb/MMBtu           | 15 – 27.5      |
| Tennessee Valley Authority<br>Johnsonville Unit 1<br>Waverly, TN               | CE T-Fired                     | 125 MW             | Coal                | 0.44-0.46<br>lb/MMBtu             | 25             |

| COMPANY / LOCATION  | UNIT TYPE                            | SIZE<br>(MMBtu/hr)     | FUEL                | NO <sub>x</sub> BASELINE<br>(ppm)               | REDUCTION<br>% |
|---|--------------------------------------|------------------------|---------------------|---|----------------|
| Tennessee Valley Authority<br>Shawnee Unit 1<br>Paducah, KY                       | B&W Front<br>Wall-Fired              | 145 MW                 | Coal                | 0.43 lb/MMBtu                                   | 25             |
| Northern Indiana Public Service<br>Schahfer Station #14                           | Cyclone-Fired                        | 520 MW                 | Coal                | SCR Reagent<br>Requirement<br>1200 lb/hr        |                |
| Northern Indiana Public Service<br>Bailly Station #8                              | Cyclone-Fired                        | 360MW                  | Coal                | SCR Reagent<br>Requirement<br>1100 lb/hr        |                |
| Northern Indiana Public Service<br>Michigan City Station #12<br>Michigan City, IN | Cyclone-Fired                        | 520 MW                 | Coal                | SCR Reagent<br>Requirement<br>1200 lb/hr        |                |
| Reliant Energy/Penelec<br>Seward Unit 15  | Tangential Fired<br>C.E.             | 1457                   | Coal                | 0.78 lb/MMBtu                                   | 55             |
| Wisconsin Electric Power Co.<br>Pleasant Prairie Unit #1<br>Kenosha, WI           | Riley Turbo                          | 6260<br>(620 MWg)      | Coal                | 0.45 lb/MMBtu                                   | 56             |
| PSE&G Mercer Station Unit 1<br>Furnace #11 & #12<br>Trenton, NJ                   | Front Wall-Fired<br>Wet Bottom       | 320 MW<br>Twin Furnace | Pulv. Coal          | 1.40 lb/MMBtu                                   | 60             |
| PSE&G Mercer Station Unit 2<br>Furnace #21 & #22<br>Trenton, NJ                   | Front Wall-Fired<br>Wet Bottom       | 320 MW<br>Twin Furnace | Pulv. Coal          | 1.40 lb/MMBtu                                   | 60             |
| PSE&G<br>Hudson Station, Unit #2<br>Jersey City, NJ                               | Foster Wheeler<br>Opposed Wall       | 660 MWg                | Coal<br>Natural Gas | 0.65 lb/MMBtu<br>0.35 lb/MMBtu                  | 40<br>40       |
| Progress Energy Carolinas<br>Asheville Unit 1<br>Skyland, NC                      | Riley Front<br>Wall-Fired            | 2173<br>(200 MW)       | Coal                | 0.58 lb/MMBtu                                   | 50             |
| Wisconsin Electric Power Co.<br>Pleasant Prairie Unit #1<br>Kenosha, WI           | Riley Turbo                          | 6260<br>(620 MWg)      | Coal                | 0.45 lb/MMBtu                                   | 20             |
| <b>Industrial/Steel Industry</b>  |                                      |                        |                     |   |                |
| China Steel Units 7 & 8<br>Taiwan - Republic of China                             | C.E. VU 40                           | 156.8                  | Coal                | 0.568 lb/MMBtu                                  | 42.9           |
| China Steel<br>Unit 6, Taiwan   | CE T-Fired<br>w/CCOFA                | 535                    | Coal                | 410 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>  | 43             |
| Demag Italimpianti S.p.A.<br>Trieste, Italy                                       | Steel plant                          | 6200                   |                     | 1200 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub> | 70             |
| MHIA National Steel<br>Portage, IN  | Direct Fired<br>Furnace              | 47.9                   | Natural Gas         | 0.30 lb/MMBtu                                   | 85             |
| Nucor Steel,<br>Hugor, S.C.   | Preheat/<br>Radiant                  | 50.8<br>20             | Natural Gas         | 0.44 lb/MMBtu<br>0.31 lb/MMBtu                  | 82<br>89       |
| NKK Steel Engineering<br>National Steel CGL #1<br>Portage, IN                     | Radiant Tube<br>Annealing<br>Furnace | 117                    | Natural Gas         | 0.26 lb/MMBtu                                   | 90             |



| COMPANY / LOCATION                                    | UNIT TYPE                            | SIZE<br>(MMBtu/hr) | FUEL                               | NO <sub>x</sub> BASELINE<br>(ppm) | REDUCTION<br>% |
|---|--------------------------------------|--------------------|------------------------------------|-----------------------------------|----------------|
| NKK Steel Engineering<br>National Steel<br>Ecorse, MI | Cont. Galv. Line                     | 117                | Natural Gas                        | 0.34 lb/MMBtu                     | 90             |
| Nucor Steel,<br>Crawfordsville, IN                    | Reheat/<br>Radiant                   | 58.8<br>14.3       | Natural Gas                        | 0.227 lb/MMBtu<br>0.581 lb/MMBtu  | 76             |
| Nucor Steel,<br>Hickman, AR                           | Preheat/<br>Radiant                  | 46.7<br>14.6       | Natural Gas                        | 0.32 lb/MMBtu<br>0.46 lb/MMBtu    | 76<br>79       |
| Protec/US Steel, CGL #1<br>Leipsic, OH                | Radiant Tube<br>Annealing<br>Furnace | 99                 | Natural Gas                        | 0.589 lb/MMBtu                    | 90             |
| Protec/US Steel, CGL #2<br>Leipsic, OH                | Radiant Tube<br>Furnace              | 76.8               | Natural Gas                        | 0.253 lb/MMBtu                    | 90             |
| Selas/BHP<br>Rancho Cucamonga, CA                     | Cont. Galv. Line                     | 29                 | Natural Gas                        | 105                               | 65             |
| WAPC Iron Dynamics<br>Butler, IN                      | Rotary Hearth                        | 435                | Natural Gas                        | 0.374 lb/MMBtu                    | 30             |
| <b>Refinery Process Units and Industrial Boilers</b>  |                                      |                    |                                    |                                   |                |
| Corn Products<br>North Carolina                       | Gasifier                             | 262                | Wood                               | 163                               | 20             |
| UNOCAL<br>Los Angeles, CA                             | Calciner<br>HRSG                     |                    | Petroleum Coke                     | 45                                | 53             |
| UNOCAL<br>Los Angeles, CA                             | CO Boiler                            | 400                | Refined Gas                        | 140                               | 68             |
| ARCO CQC Kiln<br>Los Angeles, CA                      | Calciner HRSG                        | 651                | Petroleum Coke                     | 86                                | 30             |
| BP<br>Toledo, OH                                      | CO Boiler                            | 518                | Refinery Gas                       | 95                                | 22-35          |
| MAPCO Petroleum<br>Memphis, TN                        | Bottom-Fired<br>Process Htr          | 177                | Refinery Gas,<br>Natural Gas       | 75                                | 60             |
| MAPCO Petroleum<br>Memphis, TN                        | Bottom-Fired<br>Process Htr.         | 50                 | Refinery Gas,<br>Natural Gas       | 65                                | 50 - 75        |
| Mobil Oil<br>Paulsboro, NJ                            | GT - HRSG                            | 630                | Refinery Gas                       | 75                                | 50             |
| Mobil Oil<br>Torrance, CA                             | CO Boiler                            | 614                | Refinery Gas                       | 90                                | 65             |
| Mobil Oil/Macchi<br>Yanbu, Saudi Arabia               | Package Boiler                       | (3) 265            | Vacuum Tower<br>Bottoms<br>Propane | 0.40 lb/MMBtu                     | 25             |
| Pennzoil<br>Shreveport, LA                            | CO Boiler/<br>Thermal<br>Oxidizer    |                    | CO, Refinery<br>Gas                |                                   |                |
| Pennzoil<br>Shreveport, LA                            | CO Boiler/<br>Thermal<br>Oxidizer    | 243                | Natural Gas &<br>Regen. Gas        | 0.27 lb/MMBtu                     | 74             |

| COMPANY / LOCATION                                   | UNIT TYPE                    | SIZE<br>(MMBtu/hr)                | FUEL                         | NOx BASELINE<br>(ppm)                          | REDUCTION<br>% |
|--|------------------------------|-----------------------------------|------------------------------|--|----------------|
| Powerine<br>Santa Fe Springs, CA                     | CO Boiler                    | 31 - 62                           | Refinery Fuel<br>Gas         | 105  | 60             |
| Powerine<br>Santa Fe Springs, CA                     | Package Boiler               | 31 - 62                           | Refinery Fuel<br>Gas         | 105  | 40             |
| Shell Oil<br>Martinez, CA                            | CO Boiler                    | (3) 222                           | Refinery Gas                 | 230  | 65             |
| Total Petroleum<br>Alma, MI                          | CO Boiler                    | 197                               | CO, Refinery<br>Gas          | 1.20 lb/MMBtu                                  | 67             |
| <b>Pulp &amp; Paper Industry</b>                     |                              |                                   |                              |  |                |
| Babcock and Wilcox<br>Bowater, Calhoun, TN           | BFB                          | 821                               | Wood/Sludge                  | 0.35 lb/MMBtu                                  | 62             |
| Boise Cascade<br>Intl. Falls, MN                     | Hydrograte<br>Stoker         | 395                               | Bark, Gas                    | 0.14-0.19<br>lb/MMBtu                          | 25 - 35        |
| C.C.T.<br>Verzuolo, Italy                            | Paper Sludge                 | 28.8 t/h                          |                              | 400 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub> | 50             |
| Energy Products of Idaho<br>Italy                    | BFB                          | 70.2                              | Paper/Landfill<br>Sludge     | 0.587 lb/MMBtu                                 | 60.5           |
| Garden State Paper, Unit #3<br>Garfield, NJ          | Front-Fired<br>Ind. Boiler   | 110                               | Fiber Waste                  | 0.30 lb/MMBtu                                  | 50             |
| Garden State Paper, Unit #4<br>Garfield, NJ          | Front-Fired<br>Ind. Boiler   | 172                               | Fiber Waste                  | 0.20 lb/MMBtu                                  | 30             |
| Jefferson Smurfit<br>Jacksonville, FL                | CE Grate-Fired               | 540                               | Coal, Bark, Oil              | 0.55-0.70<br>lb/MMBtu                          | 20 - 35        |
| Minergy Fox Valley<br>Aggregate Plant<br>Neeenah, WI | B & W Cyclone                | 350                               | Paper Sludge/<br>Natural Gas | 0.80 lb/MMBtu                                  | 62             |
| P. H. Glatfelter<br>Neeenah, WI                      | Sludge<br>Combustor          | 60                                | Paper Sludge                 | 570  | 50             |
| Potlatch<br>Bemidji, MN                              | Wellons<br>4-Cell Burner     | 232                               | Wood Waste                   | 0.30 lb/MMBtu                                  | 50             |
| S. D. Warren<br>Skowhegan, ME                        | CE Grate-Fired               | 900                               | Oil, Bark,<br>Biomass        | 0.30 lb/MMBtu                                  | 46             |
| Sodra Skogsagarna<br>Sweden                          | Recovery Boiler              | 900                               | Black Liquor                 | 60 mg/Nm <sup>3</sup><br>@ 3% O <sub>2</sub>   | 60             |
| Westvaco Phase I (Lukemill) #24<br>Luke, MD          | B & W Cyclone                | 550                               | Coal                         | 1.15 lb/MMBtu                                  | 50             |
| <b>Process Units</b>                                 |                              |                                   |                              |  |                |
| Alcan<br>Berea, KY (2 units)                         | Decoater/<br>Afterburner     | 30,000 lbs of aluminum<br>cans/hr | Gas                          | 90 - 130                                       | 50 - 80 +      |
| Allis Minerals<br>Oak Creek, WI                      | Rotary Kiln<br>Incinerator   | 60                                | Paper Sludge                 | 0.48 lb/MMBtu                                  | 57             |
| Dow Chemical<br>Midland, MI                          | Rotary Kiln<br>w/Afterburner | 145                               | Haz Waste                    | 720 - 740                                      | 40 - 55        |



| COMPANY / LOCATION  | UNIT TYPE                | SIZE<br>(MMBtu/hr)       | FUEL                                   | NO <sub>x</sub> BASELINE<br>(ppm)                        | REDUCTION<br>% |
|---|--------------------------|--------------------------|--|--|----------------|
| Eli Lilly<br>Lafayette, IN  | Haz Waste<br>Incinerator | 59                       | Haz Waste                              | 290  | 70             |
| Shinkong Synthetic Fiber Taiwan   | Engine<br>Generator      | 5.7 MW each              | #6 Fuel Oil                            | 1520 ppm<br>@ 13% O <sub>2</sub>                         | 85             |
| Rollins Environmental<br>Deer Park, TX  | Haz Waste<br>Incinerator | 185                      | Chlorinated<br>Chemical<br>Waste, Soil | 60 - 250   | 35 - 50        |
| Univar/Chambers Medical Waste<br>Incinerator<br>Chambers County, TX (2 units) | Simonds<br>Incinerator   | 221                      | Medical and<br>Municipal               | 0.48 lb/MMBtu  | 67.8           |
| <b>Municipal Waste Combustors</b>   |                          |                          |  |  |                |
| Ambiente Porto<br>Marghera #1 Italy   | Incinerator              | 109 t/h                  | Process Gas                            | 204 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub><br>0.28 * | 60             |
| Ambiente S.p.A.<br>Scarlino, Italy  | Incinerator              | 3 - 7 t/h                |  | 500 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>           | 60             |
| Bakelite<br>Meiderich<br>Germany ( 2 combustors)                              | Package Boiler           | 23870 Nm <sup>3</sup> /h |  | 650  | 54             |
| C.C.T.<br>Faenza<br>Italy   | Confidential             | Confidential             | Confidential                           | Confidential   | Confidential   |
| CNIM<br>Confidential<br>England   | Grate-Fired              | 28 t/h                   |  | 400  | 55             |
| Defisa<br>Maresme Spain   | Grate-Fired              | 10                       |  | 500  | 60             |
| Hamon Environmental<br>Creteil, France  | Rotary Kiln              | 32000 Nm <sup>3</sup> /h |  | 140  | 50             |
| HRCI Italy  | Grate-Fired              | 10500 Nm <sup>3</sup> /h |  | 370  | 46             |
| K.N.T.<br>Wismar, Germany   | Grate-Fired              | 61000 Nm <sup>3</sup> /h |  | 400  | 50             |
| Maguin<br>La Reunion, France  | Rotary Kiln              | 8200 Nm <sup>3</sup> /h  |  | 300  | 33             |
| Pfeiderer<br>Gutersloh, Germany   | Grate & Nozzle-<br>Fired | 93000 Nm <sup>3</sup> /h |  | 600  | 66             |
| Protecma<br>Trieste Unit 3<br>Italy   | Grate-Fired              | 43000 Nm <sup>3</sup> /h |  | 400  | 50             |
| SIVOM<br>Metz, France   | Incinerator              | 2 - 8 t/h                |  | 350 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>           | 45             |
| SMITOM<br>Vaux le Pénil, France   | Incinerator              | 2 - 8 t/h                |  | 350 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>           | 45             |

| COMPANY / LOCATION   | UNIT TYPE                       | SIZE<br>(MMBtu/hr)        | FUEL           | NO <sub>x</sub> BASELINE<br>(ppm)                  | REDUCTION<br>% |
|--|---------------------------------|---------------------------|----------------|--|----------------|
| Sirtec Nigi spA<br>Le Havre, France                                      | Waste<br>Incinerator SCR        | 63,571 Nm <sup>3</sup> /h |                | 350 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 82             |
| Sirtec Nigi spA<br>Nimes, France   | Waste<br>Incinerator SCR        | 77,000 Nm <sup>3</sup> /h |                | 400 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 87             |
| Bewag<br>Germany   | Tower                           | 150 MW                    | Heavy Oil      | 200-225 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub> | 60 - 70        |
| Bremen, Germany  | Grate Fired                     | 15 t/h                    |                | 350 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 45             |
| City of Berlin<br>Berlin, Germany  | Moving Grate                    |                           | MSW            | 160  | 69             |
| City of Berlin<br>Berlin, Germany  | Zurn Stoker                     | 167                       | MSW            | 275  | 75             |
| RWE<br>Germany   | T-Fired                         | 150 MW                    | Brown Coal     | 200-250 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub> | 50             |
| Sydskraft<br>Sweden  | PC Front-Fired                  | 500                       | Coal           | 650 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 80             |
| Yukong<br>Ulsan, Korea   | Package Boiler                  | 34 TPH                    | #6 Oil         | 260-330 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub> | 16 - 47        |
| Emmenspitz<br>Zuchwil, Switzerland                                       | Detroit Stoker                  | 137.5                     | MSW            | 110  | 60             |
| Emmenspitz<br>Zuchwil, Switzerland                                       | Moving Grate<br>Incinerator     | 121                       | MSW            | 200  | 68             |
| Tekniskaverken<br>Garstad, Sweden  | Moving Grate                    |                           | MSW            |  |                |
| Hallstehammer<br>Sweden  |                                 |                           |                |  |                |
| Wheelabrator<br>West Millbury, MA<br>(2 combustors)                      | Incinerator                     | 351 / 750 TPD             | MSW            | 300  | 32             |
| AGEA MSW<br>Ferrara, Italy   | Incinerator                     | 1 - 5 t/h                 |                | 400 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 50             |
| Alstom Power Daneco<br>Pisa, Italy                                       | Incinerator                     | 2 - 8 t/h                 |                | 400 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 50             |
| Ambiente S.p.A.<br>Porto Marghera, Italy                                 | Incinerator                     | 2 - 7 t/h                 |                | 450 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 60             |
| Ambiente S.p.A.<br>Ravenna, Italy  | Incinerator                     | 1 - 12 <sup>2</sup> t/h   |                | 500 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 60             |
| American Ref-Fuel<br>(CP) Hempstead<br>Long Island, NY<br>(3 combustors) | Deutsche Babcock<br>Grate-Fired | 320                       | MSW<br>768 T/D | 0.44 lb/MMBtu                                      | 25             |

| COMPANY / LOCATION   | UNIT TYPE                                 | SIZE<br>(MMBtu/hr) | FUEL      | NO <sub>x</sub> BASELINE<br>(ppm)                       | REDUCTION<br>% |
|--|---|--------------------|-----------|---|----------------|
| American Ref-Fuel<br>Niagara Falls, NY (2 combustors)                | Riley Grate                               | (2) 414            | RDF, MSW  | 300   | 50             |
| Ansaldo Arrezo<br>Italy  | Incinerator                               | 51 t/h             | MSW       | 460 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub><br>227 * | 56             |
| Aster, R.S.U. Cremona<br>2° linea, Italy                             | Incinerator                               | 1 - 8 t/h          |           | 400 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>          | 50             |
| Baltimore/Resco/WAPC<br>Baltimore, MD                                | Burning Grate<br>Stoker Fired             | 325                | MSW       | 0.50 lb/MMBtu   | 30             |
| Bremen, Germany (3 combustors)                                       | Grate Fired                               | 15 t/h             |           | 350 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>          | 35             |
| Bremen, Germany  | Grate Fired                               | 20 t/h             |           | 350 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>          | 35             |
| C.C.T.<br>Airasca, Italy   | Biomass                                   | 40000              |           | 400 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>          | 60             |
| C.C.T.<br>Massafra, Italy  | Biomass                                   | 95000              |           | 558 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>          | 71             |
| C.C.T.<br>Termoli, Italy   | Biomass                                   | 40000              |           | 400 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>          | 60             |
| CAECEM<br>Fort France, Martinique                                    | Incinerator                               | 2 - 7              |           | 400 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>          | 50             |
| CNIM<br>Spain  | Grate Fired                               | 30 t/h             |           | 400 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>          | 50             |
| Compagnia Energetica Bellunese<br>Castellavazzo, Italy               |   | 8 t/h              |           | 800 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>          | 50             |
| Connecticut Resource Recovery<br>Authority - Unit 13<br>Hartford, CT | CE VU 40                                  | 325                | RDF, Coal | 0.33-0.52<br>lb/MMBtu                                   | 35 - 40        |
| Covanta Energy<br>Babylon MSW<br>NY (2 combustors)                   | Zurn<br>Grate-Fired                       | 142                | MSW       | 320   | 53 - 66        |
| CRRA - Units 11 & 12<br>Hartford, CT (2 combustors)                  | C.E. VU 40                                | 326                | RDF       | 0.52 lb/MMBtu   | 40             |
| Cyclerval UK<br>Grimsby, England                                     | Incinerator                               | 1 - 7 t/h          | MSW       | 300 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>          | 40             |
| DB Riley, Central Wayne<br>Dearborn, MI (3 combustors)               | Municipal Waste<br>Combustor              | 115<br>138         | MSW       | 0.47 lb/MMBtu<br>0.48 lb/MMBtu                          | 50             |
| De Canderas<br>Cremona, Italy  | Municipal Waste<br>Combustor              |                    | MSW/RDF   | 250 @ 11% O <sub>2</sub>                                | 60             |
| Deza Vitkovice<br>Czech Republic                                     | Wall Fired Boiler                         | 362                | Oil/Mazut | 700 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>          | 36             |
| Dong Bu<br>Ansan Proj<br>Korea (2 combustors)                        | Steinmuller<br>Incinerator<br>Grate-Fired | 281                | MSW       | 200   | 75             |



| COMPANY / LOCATION                                       | UNIT TYPE                    | SIZE<br>(MMBtu/hr)        | FUEL                  | NO <sub>x</sub> BASELINE<br>(ppm)                  | REDUCTION<br>%     |
|--|------------------------------|---------------------------|-----------------------|--|--------------------|
| Dong Bu<br>Kwang Myong, Korea<br>(2 combustors)          | Municipal Waste<br>Combustor | 150 TPD                   | MSW                   | 0.59   | 65                 |
| Ecoespano<br>S.Croce sull'Arno, Italy                    | Incinerator                  | 52000 Nm <sup>3</sup> /hr |                       | 350 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 45                 |
| Falls Township<br>Falls Township, PA                     | B&W Stoker                   | (2) 325                   | MSW                   | 330 Max<br>285 Typ                                 | 50% Max<br>40% Typ |
| Fort Lewis<br>Fort Lewis, WA                             | Municipal Waste<br>Combustor | 60 tons/day               | MSW                   | 230 @ 7% O <sub>2</sub>                            | 65                 |
| Frankfurt<br>Germany (4 combustors)                      | Moving Grate                 | 660                       | MSW                   | 170mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>      | 70                 |
| G.E.A (P)<br>Pisa, Italy                                 | Incinerator                  | 1 - 7,5 t/h               |                       | 350 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 43                 |
| Haindl Schwedt<br>Germany                                | Fluidized Bed<br>Incinerator | 150                       | Pulp & Paper<br>Waste | 400-600 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub> | 50 - 66            |
| Hamm<br>Germany (3 combustors)                           | Moving Grate                 | 528                       | MSW                   | 170mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>      | 41                 |
| Hamon Research Cottrell Italia<br>Filago, Italy          | Incinerator                  | 93000                     |                       | 400 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 55                 |
| Hamon Research Cottrell Italia<br>Lagny, Italy           | Incinerator                  | 8.80 t/h                  |                       | 450 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 55                 |
| Herten<br>Germany (2 combustors)                         | Moving Grate                 | 242                       | MSW                   | 185mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>      | 60                 |
| Hornitex<br>Germany                                      | Incinerator                  | 125                       | Wood                  | 750 mg/Nm <sup>3</sup><br>370                      | 43                 |
| Keelung<br>Taiwan (2 combustors)                         | Steinmuller                  | 142                       | MSW                   | 240 mg/Nm <sup>3</sup><br>@ 10% O <sub>2</sub>     | 56                 |
| Kwang Myung<br>Seoul, Korea (2 combustors)               | Steinmuller<br>MWC           | 58                        | MSW                   | 200  | 65                 |
| Lerwick<br>Shetland Islands, UK                          | Incinerator                  | 1 - 4 t/h                 | MSW                   | 350 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 45                 |
| LIPOR II<br>Porto, Portugal                              | Incinerator                  | 2 - 24,6 t/h              |                       | 450 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 56                 |
| Meuselwitz<br>Germany                                    | Incinerator                  | 45.2                      | Sludge                | 450 mg/Nm <sup>3</sup><br>222                      | 56                 |
| Montenay Resource Recovery<br>Facility<br>Montgomery, PA | Steinmuller<br>MWC           | (2) 260                   |                       | 0.385 lb/MMBtu                                     | 50                 |
| Montenay, Units 1-4<br>Dade County, Miami, FL            | Zurn                         | 302 / 623 TPD             | RDF                   | 170 - 250  | 14946              |
| New Hanover County<br>Wrightsville Beach, NC             | Volund MWC                   | 108                       | MSW                   | 300  | 60                 |
| Nuova Romano Bolzicco S.p.A.<br>Manzano, Italy           | Biomass                      | 35000                     |                       | 400 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>     | 50                 |



| COMPANY / LOCATION                                  | UNIT TYPE                    | SIZE<br>(MMBtu/hr)         | FUEL       | NO <sub>x</sub> BASELINE<br>(ppm)                        | REDUCTION<br>%    |
|---|------------------------------|----------------------------|------------|--|-------------------|
| Pinellas County/WAPC<br>Tampa, FL<br>(3 combustors) | Municipal Waste<br>Combustor | 420                        | MSW        | 0.576 lb/MMBtu   | 33                |
| Pisa Demonstration<br>Italy                         | Incinerator                  | 64.9 t/h                   | MSW        | 350 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub><br>0.45 * | 43                |
| Pyong Chun<br>Pyung Chon City, Korea                | Municipal Waste<br>Combustor | 220<br>(200 TPD)           | MSW        | 0.53 lb/MMBtu  | 65                |
| R.S.U. Arezzo<br>Arezzo, Italy                      | Incinerator                  | 1 - 6,5 t/h                |            | 460 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>           | 57                |
| R.S.U. Cremona<br>Cremona, Italy                    | Incinerator                  | 1- 8 t/h                   |            | 500 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>           | 60                |
| Ravenna<br>Italy                                    | Municipal Waste<br>Combustor | 45,000 Nm <sup>3</sup> /hr | MSW        | 400  | 62.5              |
| Regional Waste Systems<br>ME, Units 1 & 2           | Steinmuller                  | 120                        | MSW        | 0.40 lb/MMBtu  | 33%<br>43% Design |
| Robbins Resource Recovery Facility<br>Robbins, IL   | FW CFB                       | (2) 309                    |            | 0.39 lb/MMBtu  | 48.72             |
| RWE - C2<br>Germany                                 | T-Fired                      | 75 MW                      | Brown Coal | 150-175 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>       | 40                |
| Savannah Energy Systems<br>Savannah, GA             | Municipal Waste<br>Combustor | 115                        | MSW        | 0.71 lb/MMBtu  | 50                |
| SEMASS<br>Rochester, MA                             | Riley Stoker                 | 375                        | MSW        | 220  | 50                |
| Seoul Metro Gov't<br>Mok-Dong - Seoul, Korea        | MWC                          | 62<br>150 TPD              | MSW        | 100-150mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>        | 50-67             |
| SETRAD<br>La Rochelle, France                       | Incinerator                  | 2 - 4 t/h                  |            | 300 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>           | 35                |
| SILA<br>Annecy, France                              | Incinerator                  | 1 - 4 & 2 - 6 t/h          |            | 350 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>           | 50                |
| Termomeccanica Ecologia<br>Cagliari, Italy          | Incinerator                  | 1 - 8.75 t/h               |            | 450 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>           | 60                |
| Termomeccanica Ecologia<br>Taranto, Italy           | Incinerator                  | 16 t/h                     |            | 400 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>           | 60                |
| Termomeccanica S.p.A.<br>Brindisi, Italy            | Incinerator                  | 1 - 8 t/h                  |            | 450 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>           | 66                |
| Trmice<br>Czech Republic<br>(2 combustors)          | Wall-Fired                   | 490                        | Lignite    | 341 ppvd   | 57                |
| TTR s.r.l.<br>Busto Arsizio, Italy                  | Incinerator                  | 2 - 5 t/h                  |            | 400 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>           | 50                |

| COMPANY / LOCATION   | UNIT TYPE                             | SIZE<br>(MMBtu/hr) | FUEL        | NO <sub>x</sub> BASELINE<br>(ppm)              | REDUCTION<br>% |
|--|---------------------------------------|--------------------|-------------|--|----------------|
| TTR s.r.l.<br>Trieste, Italy   | Incinerator                           | 2 - 5 t/h          |             | 400 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub> | 50             |
| Tuntex Kaohsiung MSW<br>Taiwan (3 combustors)                            | Deutsche<br>Babcock<br>Incinerator    | 120 each           | MSW         | 183 mg/Nm <sup>3</sup><br>@ 10% O <sub>2</sub> | 42             |
| Ulm<br>Germany   | Bubbling Bed<br>Sludge<br>Incinerator |                    | Sludge      |  |                |
| Vitkovice<br>Czech Republic  | Front Wall-Fired                      | 250                | Hard Coal   | 600 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub> | 50             |
| Westchester County/WAPC<br>New York, NY (3 combustors)                   | Municipal Waste<br>Combustor          | 325                | MSW         | 0.50 lb/MMBtu                                  | 30             |
| Wheelabrator<br>North Broward, FL (3 combustors)                         | Incinerator                           | 351 / 750 TPD      | MSW         | 300  | 32             |
| Wheelabrator<br>South Broward, FL (3 combustors)                         | Incinerator                           | 351 / 750 TPD      | MSW         | 300  | 32             |
| Wheelabrator RESCO<br>Bridgeport, CT (3 combustors)                      | Grate-Fired                           | 281                | MSW         | 300  | 50             |
| Wheelabrator RESCO<br>Saugus, MA (2 combustors)                          | Incinerator                           | 351 / 750 TPD      | MSW         | 300  | 32             |
| Wheelabrator<br>Concord, NH (2 combustors)                               | Incinerator                           | 110 / 250 TPD      | MSW         | 300  | 32             |
| Wheelabrator<br>Gloucester, NJ (2 combustors)                            | Incinerator                           | 109 / 250 TPD      | MSW         | 300  | 32             |
| Wheelabrator<br>McKay Bay, FL (4 combustors)                             | Incinerator                           | 108 / 250 TPD      | MSW         | 306  | 51             |
| Wheelabrator<br>North Andover, MA (2 combustors)                         | Incinerator                           | 351 / 750 TPD      | MSW         | 300  | 32             |
| Wilrijk, Germany   | Grate Fired                           | 9.6 t/h            |             | 350 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub> | 50             |
| Winterthur (1)<br>Switzerland  | Sludge<br>Incinerator                 | 8.34               | Sludge      | 200-300 mg/ Nm <sup>3</sup>                    | 60 - 73        |
| Yilan<br>Taiwan (2 combustors)   | Steinmuller                           | 142                | MSW         | 240 mg/Nm <sup>3</sup><br>@ 10%                | 56             |
| <b>Coal-, Wood-, Tire-Fired Industrial and IPP/Co-Generation Boilers</b> |                                       |                    |             |  |                |
| Hamon Research Cottrell Italia<br>Turkey (7 units)                       | Diesel SCR                            |                    |             |  |                |
| General Electric<br>Lynn, MA   | B&W "D" Type<br>Pkg. Boiler           | 236                | #6 Oil, Gas | 0.28-0.31<br>lb/MMBtu                          | 40 - 60        |
| Honey Lake Power<br>Susanville, CA                                       | Stoker-Fired                          | 480                | Wood        | 0.21 lb/MMBtu                                  | 52             |
| Oxford Energy<br>Modesto #2,<br>Wesley, CA                               | Moving Grate<br>Incinerator           | 90                 | Tires       | 0.13 lb/MMBtu                                  | 40             |



| COMPANY / LOCATION  | UNIT TYPE                 | SIZE<br>(MMBtu/hr) | FUEL                       | NO <sub>x</sub> BASELINE<br>(ppm)             | REDUCTION<br>% |
|---|---------------------------|--------------------|----------------------------|---|----------------|
| Ultrasystems<br>Fresno, CA  | CFB                       | 280                | Wood                       | 150   | 70             |
| Yankee Energy<br>Dinuba, CA   | CFB                       | 190                | Wood Waste                 | 0.10-0.18<br>lb/MMBtu                         | 40 - 75        |
| Tekniskaverken<br>Linköping P3<br>Sweden                            | Stoker                    |                    | Wood                       | 800mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub> | 50             |
| ABB Okeelanta<br>Okeelanta, FL                                      | Grate-Fired<br>Stoker     | 660                | Bagasse Wood,<br>Coal      | 0.40-0.20<br>lb/MMBtu                         | 40 - 60        |
| ABB Osceola<br>Osceola, FL  | Grate-Fired<br>Stoker     | 660                | Bagasse Wood,<br>Coal      | 0.40-0.20<br>lb/MMBtu                         | 40 - 60        |
| AES<br>Guyama, Puerto Rico (2 units)                                | CFB                       | 250 MW             | Coal                       | 0.13 lb/MMBtu                                 | 23             |
| Alternative Energy, Inc.<br>Ashland, ME                             | Zurn Stoker               | 500                | Wood                       | 0.30 lb/MMBtu                                 | 50             |
| Alternative Energy, Inc.<br>Cadillac, MI                            | Zurn Stoker               | 500                | Wood                       | 0.30 lb/MMBtu                                 | 50             |
| Alternative Energy, Inc.<br>Northeast Empire<br>Livermore Falls, ME | Zurn Stoker               | 500                | Wood                       | 0.30 lb/MMBtu                                 | 50             |
| Black & Veatch<br>Genessee, MI                                      | ABB CE Stoker             | 473                | Wood                       | 0.47 lb/MMBtu                                 | 60             |
| Black & Veatch<br>Grayling, MI                                      | Zurn Stoker               | 440                | Biomass                    | 0.26 lb/MMBtu                                 | 60             |
| Celanese<br>Narrows, VA   | Front Wall-Fired          | 315                | Coal                       | .360 lb/MMBtu                                 | 35 - 40        |
| Chewton Glen Energy<br>Ford Heights, IL                             | Grate-Fired               | 240                | Shredded Tires             | 0.195 lb/MMBtu                                | 60             |
| Cogentrix<br>Richmond, VA (8 units)                                 | CE Stoker                 | (8) 28 MW          | Coal                       | 350   | 40             |
| Far East Textiles<br>Hsihpu, Taiwan                                 | Stoker Boiler             | 190                | Coal                       | 550 @ 6% O <sub>2</sub>                       | 50             |
| FT GmbH<br>Germany (5 units)  | Fire Tube<br>Pkg. Boilers | 10 - 20 MW         | Heavy Oil                  | 700-800mg/ Nm <sup>3</sup>                    | 40 - 50        |
| Georgia Pacific<br>Brookneal, VA                                    | Wellons 4-Cell            | 236                | Mixed Wood                 | 0.33 lb/MMBtu                                 | 38             |
| Georgia Pacific<br>Mt. Hope, WV                                     | Cell-fired                | 240                | Bark/Dust                  | 0.25 lb/MMBtu                                 | 20             |
| Hyundai<br>Korea Kumho Petrochemical                                | CFB                       | 926                | Pulv. Coal                 | 275   | 56             |
| I.P. Masonite<br>Towanda, PA  | B & W                     | 250                | Sludge/Wood<br>Waste, Coal | 0.4 lb/MMBtu                                  | 50             |

| COMPANY / LOCATION  | UNIT TYPE                                      | SIZE<br>(MMBtu/hr) | FUEL                                   | NO <sub>x</sub> BASELINE<br>(ppm)                | REDUCTION<br>% |
|---|--|--------------------|--|--|----------------|
| Kenetech Energy<br>Fitchburg, MA                            | Riley Stoker                                   | 225                | Wood                                   | 0.26 lb/MMBtu                                    | 47             |
| Korea ICC Units 1 - 3<br>Kumi Heat & Power Station<br>Korea | Front Wall-Fired                               | 530<br>530<br>530  | Pulv. Coal<br>Pulv. Coal<br>Pulv. Coal | 710<br>700<br>710                                | 53<br>53<br>40 |
| LFC<br>Hillman, MI  | Grate-Fired                                    | 190                | Wood                                   | 0.22 lb/MMBtu                                    | 30             |
| McMillan Bloedel<br>Clarion, PA                             | EPI Fluid Bed<br>Combustor                     | 500                | Wood Waste/<br>Hog Fuel                | 100  | 42             |
| Michigan State Univ., Unit #4<br>East Lansing, MI           | CFB  | 460                | Coal                                   | 247  | 57             |
| Michigan State Univ., Units #1-3<br>East Lansing, MI        | Wall Fired Boiler                              | 320<br>320<br>420  | Coal                                   | 0.38-0.40<br>lb/MMBtu                            | 34-38          |
| Nykoping, Units 1-3<br>Gotaverken Energy<br>Sweden          | CFB  | 135                | Coal                                   | 120-130mg/Nm <sup>3</sup><br>@ 1% O <sub>2</sub> | 70             |
| Oxford Energy<br>Sterling, CT                               | Grate-Fired                                    | (2) 170            | Tires                                  | 0.15 lb/MMBtu                                    | 50             |
| Ridge Generating<br>Polk County, FL                         | Zurn Stoker                                    | 550                | Wood                                   | 0.35 lb/MMBtu                                    | 57             |
| Riley Ultrasystems II<br>Weldon, NC                         | Riley<br>Front-Fired<br>Boiler                 | 505                | Pulv. Coal                             | 0.33 lb/MMBtu                                    | 50             |
| Ryegate Power Station<br>Ryegate, VT                        | Riley Stoker                                   | 300                | Wood                                   | 0.20 lb/MMBtu                                    | 30             |
| Sierra Pacific<br>Bohemia Plant<br>Lincoln, CA              | Cell-Fired                                     | (2) 130            | Biomass                                | 0.42 lb/MMBtu                                    | 50             |
| Sonoco<br>Huntsville, SC                                    | FW/<br>Pyropower CFB                           | 145                | Coal                                   | 195  | 67             |
| Standardkessel<br>Germany (31 units)                        | Fire Tube<br>Pkg. Boilers                      | 10 - 20 MW         | Heavy Oil                              | 700-800 mg/Nm <sup>3</sup>                       | 40 - 50        |
| Strakonice<br>Czech Republic (2 units)                      | High Front Wall-<br>Fired & Low<br>Grate Fired | 36-40              | Lignite Brown<br>Coal                  | 600 mg/Nm <sup>3</sup>                           | 50             |
| Tekniskaverken<br>Linkoping P1<br>Sweden                    | Stoker   | 275                | Coal                                   | 300-350mg/Nm <sup>3</sup><br>@ 4% O <sub>2</sub> | 65             |
| Trigen Cnergy<br>St. Paul, MN                               | Front Wall<br>Grate-Fired                      | 555                | Wood Waste                             | 0.34 lb/MMBtu                                    | 56             |
| Zachry Energy<br>Hurt, VA                                   | Riley Stoker                                   | (3) 390            | Wood                                   | 0.20 lb/MMBtu                                    | 46             |

| COMPANY / LOCATION                                 | UNIT TYPE                     | SIZE<br>(MMBtu/hr)   | FUEL                   | NO <sub>x</sub> BASELINE<br>(ppm)               | REDUCTION<br>% |
|--|-------------------------------|--|------------------------|---|----------------|
| Combustion Turbine<br>West Coast Location          | HRSG                          | 100 MW   | Gas                    | SCR Reagent<br>Requirement<br>100 lb/hr         |                |
| Peerless Manufacturing<br>MATEP - Boston, MA       | HRSG                          | 100 MW   | Gas                    | SCR Reagent<br>Requirement<br>2 @ 50 lb/hr      |                |
| <b>Chemical Industry</b>                           |                               |  |                        |   |                |
| BP Chemicals<br>Green Lake, TX                     | AOG Incin.<br>HRSG            | 34   | Waste Gas              | 330   | 80 +           |
| BP Chemicals<br>Green Lake, TX<br>(3 incinerators) | AOG Incin.<br>HRSG            | 398,757 lb/hr Flue Gas<br>398,757 lb/hr Flue Gas<br>238,361 lb/hr Flue Gas | Absorber<br>OFF<br>Gas | 238<br>238<br>150                               | 50<br>50<br>50 |
| Far East Textile<br>Taiwan                         | Front-Fired                   |  | Coal                   |   | 50             |
| Formosa Plastics<br>Kaohsiung, Taiwan              | Front-Fired                   | 331  | Coal                   | 500   | 60             |
| Formosa Plastics<br>Kaohsiung, Taiwan              | Front-Fired                   | 331  | Coal                   | 500 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub>  | 60             |
| Miles, Inc.<br>Kansas City, MO                     | Carbon Furnace<br>Afterburner | 16   | Chemical Waste         | 150   | 35             |
| N American Chem. Corp.<br>Trona, CA                | T-Fired                       | (2) 75 MW  | Coal                   | 200   | 40             |
| <b>Cement Kilns</b>                                |                               |  |                        |   |                |
| Ash Grove Cement<br>Seattle, WA                    | Cement Kiln/<br>Pre-Calciner  | 160 tons<br>solids/hr  | Coal, Gas              | 350 - 600#/hr                                   | > 80           |
| Korean Cement<br>Dong Yang Cement,<br>Korea        | New Suspension<br>Calciner    |  | Coal                   | 1.27 lb/MMBtu                                   | 45             |
| Lehigh Portland Cement<br>Mason City, IA           | Cement Kiln/<br>Pre-Calciner  | 368  | Coal, Gas              | 0.95-1.35<br>lb/MMBtu                           | 25 - 35        |
| Plant Name & Location Confidential                 |                               |  |                        | 1500 mg/Nm <sup>3</sup><br>@ 11% O <sub>2</sub> | 45             |
| Taiwan Cement<br>Units #3, #5, & #6                | Cement Kiln/<br>Pre-Calciner  | 260<br>697<br>658  | Coal<br>Coal<br>Coal   | 1.29<br>1.58<br>0.92                            | 50<br>45<br>25 |
| Wulfrath Cement<br>Germany                         | Cement Kiln                   | 140  | Lignite                | 1000 mg/Nm <sup>3</sup><br>500                  | 90             |

- (1) All units listed are commercial installations, unless otherwise indicated. Commercial includes units in the design and installation phases.
- (2) Company/Locations which are not named are requirements of Confidentiality Agreements. (D) Denotes "Demonstration."
- (3) NO<sub>x</sub> Reduction values are not necessarily the limit of the technology. These values may be the guaranteed limits.
- (4) lb/MMBtu
- (5) Actual limit = 0.33 lb/MMBtu



## APPENDIX 2: Selected Applications of Ammonia-Based SNCR, by Industry

| COMPANY/LOCATION<br>(1)   | UNIT TYPE                | SIZE<br>(MMBtu/hr)     | FUEL       | NO <sub>x</sub> BASELINE<br>(ppm) | REDUCTION<br>(%) (2) |
|---|--------------------------|------------------------|------------|-----------------------------------|----------------------|
| <b>Stoker-Fired and Pulverized Coal-Fired Boilers</b>                 |                          |                        |            |                                   |                      |
| Atavista, VA  | Stoker Fired             | 2@380                  | Wood/Coal  | 321                               | 50-65                |
| Buena Vista   | Stoker Fired             | 2@385                  | Coal       | 324                               | 54-66                |
| KMW<br>Mainz, Germany   | Pulverized Coal          | 2@450                  | Coal       | 600                               | 83                   |
| Hopewell, VA  | Stoker Fired             | 2@385                  | Coal       | 324                               | 54-66                |
| Modesto, CA   | Stoker Fired             | 2@204                  | Tires      | N/A                               | 78                   |
| Showa Denko<br>Oita, Japan  | Pulverized Coal          | 1000                   | Coke       | 315                               | 57                   |
| STEAG<br>Herne, Germany   | Pulverized Coal          | 4500                   | Coal       | 250                               | 55                   |
| <b>Coal-Fired Boilers</b>   |                          |                        |            |                                   |                      |
| Kraftwerke Mainz<br>Wiesbaden/Deutsche Babcock Anlagen AG<br>Germany  | Cyclone                  | 2@433                  | Coal       |                                   | 83                   |
| Northeast Utilities<br>Merrimack Station Unit 1<br>Bow, New Hampshire | Cyclone                  |                        | Coal       |                                   |                      |
| Rio Bravo Jasmin<br>Rio Bravo, CA                                     | Circulating Fluid<br>Bed | 391                    | Coal       |                                   | 80                   |
| Rio Bravo Poso<br>Rio Bravo, CA                                       | Circulating Fluid<br>Bed | 391                    | Coal       |                                   | 80                   |
| Stockton Cogen<br>Stockton, CA  | Circulating Fluid<br>Bed | 620                    | Coal       |                                   | N/A                  |
| Veba Kraftwerke A.G.<br>Gelssenkirchen, Germany                       | Cyclone                  | 730                    | Coal       |                                   | 38                   |
| <b>Stoker-Fired Wood-Fueled Boilers</b>                               |                          |                        |            |                                   |                      |
| Brawley, CA   | Stoker Fired             | 250                    | Wood       | 400                               | 60                   |
| Burney, CA  | Stoker Fired             | 2@478                  | Wood       | 116                               | 52                   |
| Long Beach, CA  | Stoker Fired             | 200                    | Wood       | 325                               | 60                   |
| Sacramento, CA  | Stoker Fired             | 164                    | Wood       | 220                               | 59                   |
| Shasta, CA  | Stoker Fired             | 3@903                  | Wood       | 75-90                             | 40-52                |
| Susanville, CA  | Stoker Fired             | 500                    | Wood       | 130                               | 58                   |
| Terra Bella, CA   | Stoker Fired             | 158                    | Wood       | 100                               | 50                   |
| Tracy, CA   | Stoker Fired             | 275                    | Wood       | 310                               | 75                   |
| <b>Circulating Fluidized and Bubbling Bed Boilers</b>                 |                          |                        |            |                                   |                      |
| Chinese Station, CA   | Bubbling Bed             | 315                    | Wood       | 125                               | 80                   |
| Chowilla, CA  | Bubbling Bed             | 152                    | Wood       |                                   |                      |
| Colmac, CA  | Fluidized Bed            | 590 total<br>[2 units] | Coal       |                                   |                      |
| Combustion Power, CA  | Fluidized Bed            |                        | Coal, Coke |                                   |                      |
| El Nido, CA   | Bubbling Bed             | 175                    | Wood       |                                   |                      |
| Fresno, CA  | Fluidized Bed            | 350                    | Wood       | 120                               | 76                   |
| Jasmine, CA   | Fluidized Bed            | 394                    | Coal       | 150                               | 80                   |
| Madera, CA  | Bubbling Bed             | 384                    | Wood       |                                   |                      |
| Mendota, CA   | Fluidized Bed            | 349                    | Wood       | 120                               | 80                   |
| Poso, CA  | Fluidized Bed            | 394                    | Coal       | 150                               | 80                   |
| Rocklin, CA   | Fluidized Bed            | 340                    | Wood       | 120                               | 76                   |
| Stockton, CA  | Fluidized Bed            | 620                    | Coal       |                                   |                      |
| Woodland, CA  | Fluidized Bed            | 330                    | Wood       | 120                               | 76                   |
| <b>Municipal Solid Waste Incinerators</b>                             |                          |                        |            |                                   |                      |
| Commerce  |                          | 300 (3)                |            | 200                               | 60                   |
| Long Beach, CA  |                          | 3@470 (3)              |            | 200                               | 70                   |
| Stanislaus County   |                          | 2@400 (3)              |            | 200                               | 67                   |

| COMPANY/LOCATION<br>(1)                                | UNIT TYPE | SIZE<br>(MMBtu/hr) | FUEL    | NO <sub>x</sub> BASELINE<br>(ppm) | REDUCTION<br>(%) (2) |
|--|-----------|--------------------|---------|-----------------------------------|----------------------|
| Unit "M"   |           | 750 (3)            |         | 320                               | 65                   |
| Minneapolis  |           | 2@600 (3)          |         | 240                               | 60                   |
| Spokane  |           | 2@400 (3)          |         | 300                               | 45                   |
| Munich, Germany  |           | 930 (3)            |         | 190                               | 70                   |
| Huntington, Long Island                                |           | 3@480 (3)          |         | 350                               | 60                   |
| Essex County   |           | 3@770 (3)          |         | 190                               | 60                   |
| Bremerhaven, Germany                                   |           |                    |         |                                   |                      |
| Union County   |           | 3@480 (3)          |         | 350                               | 70                   |
| <b>Vapor, Sludge, and Hazardous Waste Incinerators</b> |           |                    |         |                                   |                      |
| Carson, CA   |           | 2@204              | Sludge  | 350                               | 65                   |
| Deepwater, NJ  |           | 2@103              | Sludge  | 265                               | 77                   |
| Gaviota, CA  |           | 20                 | Vapor   | 112                               | 70                   |
| Gladstone, Australia                                   |           | 57                 | Vapor   | 2000                              | 91                   |
| Germany  |           |                    | Vapor   |                                   |                      |
| <b>Gas- and Oil-Fired Industrial Boilers</b>           |           |                    |         |                                   |                      |
| TSK<br>Kawasaki, Japan                                 |           | 215                | Oil/Gas |                                   | 55                   |
| TSK<br>Kawasaki, Japan                                 |           | 1135               | Oil/Gas |                                   | 57                   |
| TSK<br>Kawasaki, Japan                                 |           | 1135               | Oil/Gas |                                   | 55                   |
| Mitsui Petrochemical<br>Japan                          |           | 340                | Oil     |                                   | 53                   |
| Tonen<br>Kawasaki, Japan                               |           | 400                | CO/Gas  |                                   | 50                   |
| Chancellor- Western Oil<br>Santa Fe Springs, CA        |           | 50                 | Crude   |                                   | 65                   |
| Champlin Petroleum<br>Wilmington, CA                   |           |                    | Oil/Gas |                                   | 65                   |
| Mohawk Petroleum<br>Bakersfield, CA                    |           | [2 units]          | Oil/Gas |                                   | 60-70                |
| Oxnard Refinery<br>Oxnard, CA                          |           | 18.5               | Crude   |                                   | 30                   |
| Santa Fe Energy<br>Santa Fe Springs, CA                |           | 3@150              | Crude   |                                   |                      |
| Getty Oil<br>California                                |           |                    | Crude   |                                   |                      |
| TSK<br>Kawasaki, Japan                                 |           | 574                | Oil/Gas |                                   | 65                   |
| Golden West Refinery<br>Santa Fe Springs, CA           |           | 60                 | CO      |                                   | 75                   |
| <b>Glass Melting Furnaces</b>                          |           |                    |         |                                   |                      |
| PPG Industries<br>Fresno, CA                           |           | 150                | Gas     |                                   | 60                   |
| LOF Glass<br>Lathrop, CA                               |           | 200                | Gas/Oil |                                   | 51                   |
| AGF Industries<br>Los Angeles, CA                      |           | 125                | Gas     |                                   | 61                   |
| Sierra Envr. & GAF<br>Irwindale, CA                    |           | 29                 | Gas     |                                   | 70                   |
| SHOTT<br>Germany                                       |           |                    |         |                                   |                      |
| <b>Oil- and Gas-Fired Heaters</b>                      |           |                    |         |                                   |                      |
| Tonen<br>Kawaski, Japan                                |           | 515 and 190        | Gas     |                                   | 63                   |
| Kyokuto Petroleum<br>Chiba, Japan                      |           | 2@250              | Oil/Gas |                                   | 51 to 53             |



| COMPANY/LOCATION<br>(1)                      | UNIT TYPE       | SIZE<br>(MMBtu/hr)      | FUEL    | NO <sub>x</sub> BASELINE<br>(ppm) | REDUCTION<br>(%) (2) |
|--|-----------------|-------------------------|---------|-----------------------------------|----------------------|
| Champlin Petroleum<br>Wilmington, CA         |                 | 627 total<br>[13 units] | Oil/Gas |                                   | 50 to 60             |
| Mohawk Petroleum<br>Bakersfield, CA          |                 | 349 total<br>[4 units]  | Oil/Gas |                                   | 60 to 70             |
| Fletcher Oil and Refining<br>Wilmington, CA  |                 | 47 total<br>[2 units]   | Gas     |                                   | 45 to 65             |
| Independant Valley Energy<br>Bakersfield, CA |                 | 165 total<br>[4 units]  | Gas     |                                   | 65 to 75             |
| Chevron Research<br>San Francisco, CA        |                 | 315                     | Gas     |                                   | 69                   |
| Monsanto<br>Carson, CA                       |                 | 23                      | Oil     |                                   | 43                   |
| PPG Industries<br>Fresno, CA                 | Glass Furnace   | 150                     | Gas     |                                   | 60                   |
| LOF Glass<br>Stockton, CA                    | Glass Furnace   | 200                     | Gas/Oil |                                   | 51                   |
| Mendota Biomass<br>Mendota, CA               | Circ. Fluid Bed | 349                     | Wood    |                                   | 72                   |
| Rocklin<br>Rocklin, CA                       | Circ. Fluid Bed | 340                     | Wood    |                                   | 76                   |
| Sierra Envr. and GAF<br>Irwindale, CA        | Glass Furnace   | 29                      | Gas     |                                   | 70                   |
| SHOTT<br>Germany                             | Glass Furnace   |                         | Gas     |                                   |                      |

- (1) All units listed are commercial installations, unless otherwise indicated. Commercial includes units in the design and installation phases.
- (2) NO<sub>x</sub> Reduction values are the guarantees.
- (3) Tons/day.



1. Smith, D.J., "NO<sub>x</sub> Emission Control Demands a Range of Solutions", Power Engineering, July, 1992, page 45.
2. Sandell, M.A., and M.T. Hoydick, "Selective Non-Catalytic Reduction of NO<sub>x</sub> Control", presented at the 1992 Spring Gulf Coast Co-Generation Association Meeting, April 21-22, 1992, Houston, Texas.
3. Sun, W.H., and J.E. Hofmann, "Reaction Kinetics of Post Combustion NO<sub>x</sub> Reduction with Urea", presented at the AFRC 1991 Spring Members Meeting, March 18-19, 1991, Hartford, CT.
4. Hurst, B.E., White, C.M. "Thermal De-NO<sub>x</sub>: A Commercial Non-Catalytic NO<sub>x</sub> Reduction Process for Waste to Energy Applications." Presented at the ASME 12th Biennial National Waste Processing Conference, Denver, June 2, 1986.
5. Comparato, J.R., Buchs, R.A., Arnold, D.S. and Bailey, L.K., "NO<sub>x</sub> Reduction at the Argus Plant Using the NOxOUT Process," EPA/EPRI 1991 Joint Symposium on Stationary Combustion NO<sub>x</sub> Control, Washington, D.C., March 25-28, 1991.
6. Huhmann, A.L., Wallace, A.J., Jantzen, T., O'Leary, J.H. "Evaluation of Retrofitted Post Combustion NO<sub>x</sub> Control Technology on a Wet Bottom, Coal-Fired Boiler." Presented at the U.S. Department of Energy Conference on Selective Catalytic and Non-Catalytic Reduction for NO<sub>x</sub> Control, Pittsburgh, May 15-16, 1997.
7. Tsai, T.S., Ariagno, L., Cote, R., Staudt, J.E., Casill, R.P. "Living with Urea Selective Non-Catalytic NO<sub>x</sub> Reduction at Montaup Electric's 112 MWe PC Boiler." Presented at ICAC Forum '96, Baltimore, March 19-20, 1996.
8. Ciarlante, V., Romero, C.E. "Design and Characterization of a Urea-Based SNCR System for a Utility Boiler." Presented at the EPRI-DOE-EPA Combined Utility Air Pollution Control Symposium, Washington, D.C., August 25-29, 1997.
9. Ellerhorst, R.; Edvardsson, C. "Experience with NO<sub>x</sub> Control at T.B. Simon CFB Boiler at Michigan State University - Case History." Presented at the Council of Industrial Boiler Owners NO<sub>x</sub> Control VIII Conference, Philadelphia, Pennsylvania, March 7-8, 1995.
10. Malone, P.M., Sun, W.H. "Cardinal Unit 1: Large Scale SNCR Demonstration Project." Presented at ICAC Forum 2000, Rosslyn, VA, March 23-24, 2000.
11. Durso, R.A., Trippel, C.E. "Combustion Tempering in Conjunction with SNCR Reduces NO<sub>x</sub> Emission Nearly 60 % on a Natural Gas Fired Cyclone Boiler." Presented at ICAC Forum 2000, Rosslyn, VA, March 23-24, 2000.
12. Trego, P., St. Laurent, G., Broderick, R.G., Schindler, E. "Burner Optimizations in Conjunction with SNCR Reduced NO<sub>x</sub> Emissions Over 70 % on Coal-Fired Boilers." Presented at ICAC Forum 2000, Rosslyn, VA, March 23-24, 2000.
13. Lövblad, R., Moberg, G., Olausson, L., Boström, C. "NO<sub>x</sub> Reduction from a Recovery Boiler by Injection of an Enhanced Urea Solution (NOxOUT Process)." Presented at the TAPPI Environmental Conference, San Antonio, Texas, April 7-10, 1991.
14. Braczyk, E.J.; Sload, A.W.; Arak, L.M.; Johnson, R.A.; Albanese, V.M. "Cost-Effectiveness of NO<sub>x</sub> Control Retrofit at Salem Harbor Station." Presented at PowerGen '94, Orlando, Florida, December 7-9, 1994.
15. Himes, R.; Hubbard, D.; West, Z.; Stallings, J. "A Summary of SNCR Applications to Two Coal-Fired Wet Bottom Boilers." Presented at the EPRI/EPA Joint Symposium on Stationary Combustion NO<sub>x</sub> Control, Kansas City, Missouri, May 19, 1995.
16. Utility Generation Report, Power Engineering, August 1991.
17. Braczyk, E.J.; Sload, A.W.; Arak, L.M.; Johnson, R.A.; Albanese, V.M. "Cost-Effectiveness of NO<sub>x</sub> Control Retrofit at Salem Harbor Station." Presented at PowerGen '94, Orlando, Florida, December 7-9, 1994.
18. O'Leary, J., Sun, W., Afonso, R., Sload, A. "SNCR Reagent Reduction Through Innovative System Controls at Salem Harbor Station Unit 3." Presented at the U.S. Department of Energy Conference on Selective Catalytic and Non-Catalytic Reduction for NO<sub>x</sub> Control, Pittsburgh, May 15-16, 1997.
19. Hofmann, J.E., von Bergmann, J., Bökenbrink, D., and Hein, K., "NO<sub>x</sub> Control in a Brown Coal-Fired Utility Boiler." Presented at the EPRI/EPA Symposium on Stationary Combustion NO<sub>x</sub> Control, San Francisco, CA, March 8, 1989; Comparato, J.R., Buchs, R.A., Arnold, D.S., "NO<sub>x</sub> Reduction at the Argus Plant Using the NOxOUT Process." Presented at the EPRI/EPA Symposium on Stationary Combustion NO<sub>x</sub> Control, Washington, D.C., March 1991; Sun, W.H., Stamatakis, P., and Grimard, F.X., "NOxOUT Process Demonstration on 325 MW Oil-Fired Boiler." ENEL, Piombino, Italy (Nalco Fuel Tech - Unpublished).
20. Jantzen, T.M., Zammit, K.D. "Hybrid Post Combustion NO<sub>x</sub> Control." Presented at the U.S. Department of Energy Conference on Selective Catalytic and Non-Catalytic Reduction for NO<sub>x</sub> Control, Pittsburgh, May 15-16, 1997; Nylander, J., and Krigmont, H.V., "Evaluation of a Full-Scale Hybrid NO<sub>x</sub> Control System at SDG&E's Encina Power Plant." Presented at the EPRI/EPA Joint Symposium on Stationary Combustion NO<sub>x</sub> Control, Bal Harbour, FL, May 24-27, 1995.
21. Wallace, A.J., Gibbons, F.X., Roy, R.O., O'Leary, J.H., Knell, E.W. "Demonstration of SNCR, SCR,

- 30 and Hybrid SNCR/SCR NO<sub>x</sub> Control Technology on a Pulverized Coal, Wet-Bottom Utility Boiler” Presented at ICAC Forum ’96, Baltimore, Maryland, March 19-20, 1996.
22. Roll, D.J., and W.B. Rady, “AES Greenidge Multi-Pollutant Control Project,” Air & Waste Management Luncheon Meeting, December 13, 2006, Rochester, New York, [www.netl.doe.gov/technologies/coalpower/cctc/PPII/bibliography/demonstration/environmental/bib\\_greenidge.html](http://www.netl.doe.gov/technologies/coalpower/cctc/PPII/bibliography/demonstration/environmental/bib_greenidge.html)