

# Human Health Criteria Treatment Technology Review and Cost Assessment

Presented to AIC Water Summit  
January 23, 2018

Tom Dupuis – Sr. Project Manager, HDR  
Dave Clark – Senior Vice President, HDR

# Cities Affected in Idaho

- Wastewater discharges to designated public drinking surface water supplies (DWS) will likely be most affected if much lower As HHC are established (by DEQ or EPA)
- AIC research to date:
  - At least 54 cities have wastewater discharges to surface waters designated DWS
  - Located throughout the state

# Technology Capability and Cost Cannot be Ignored

A coalition of NPDES Permittees sought answers on three questions:

- Are there wastewater treatment technologies that will ensure achievement of stringent numeric water quality standards?
- At what cost?
- Will there be associated adverse collateral environmental impacts?

## Study Sponsorship

- Association of Washington Business
- Association of Washington Cities
- Washington State Association of Counties

# Introducing the Study

- Washington was committed to updating human health-based water quality standards
- Dept. of Ecology began advisory committee process in 2012; a proposed regulation was expected in early spring 2014
- Many complex and challenging scientific, legal, regulatory policy issues; much stakeholder interest
- HDR study completed in December 2013
- Ultimately, EPA R10 promulgated HHC for WA,
  - 0.018  $\mu\text{g}/\text{L}$  for arsenic

# Study Design

- Create a conservative study scenario based on best information available in spring 2013
- Starting point: characterize wastewater quality from a well-operated secondary treatment system representing “all known available and reasonable methods of treatment” (AKART). 231 municipal and 187 industrial permittees.
- Limit the analysis to four troublesome pollutants: PCBs, mercury, arsenic, and a polycyclic aromatic hydrocarbon (benzo(a)pyrene).
- Use WDOE and permittee wastewater data to define the range of pollutant concentrations in secondary-treated wastewater.
- Assume ambient water quality criteria need to be achieved at point of discharge; i.e., water quality-based effluent limit

**Table 1: Summary of Effluent Discharge Toxics Limits**

| Constituent    | Human Health Criteria based Limits to be met with no Mixing Zone (µg/L) | Basis for Criteria  | Typical Concentration in Municipal Secondary Effluent (µg/L) | Typical Concentration in Industrial Secondary Effluent (µg/L) | Existing Washington HHC (water + org.), NTR (µg/L) |
|----------------|---|---|--|---|--|
| PCBs           | 0.0000064   | Oregon Table 40 Criterion (water + organisms) at FCR of 175 grams/day | 0.0005 to 0.0025 <sup>b,c,d,e,f</sup>                        | 0.002 to 0.005 <sup>i</sup>                                   | 0.0017   |
| Mercury        | 0.005   | DEQ IMD <sup>a</sup>  | 0.003 to 0.050 <sup>h</sup>                                  | 0.010 to 0.050 <sup>h</sup>                                   | 0.140  |
| Arsenic        | 0.018   | EPA National Toxics Rule (water + organisms) <sup>k</sup>             | 0.500 to 5.0 <sup>j</sup>                                    | 10 to 40 <sup>j</sup>   | 0.018  |
| Benzo(a)Pyrene | 0.0013  | Oregon Table 40 Criterion (water + organisms) at FCR of 175 grams/day | 0.00028 to 0.006 <sup>b,g</sup>                              | 0.006 to 1.9  | 0.0028   |

# Study Design

- Conduct literature review of advanced treatment technologies targeting the four pollutants. Select the two or three most promising technologies. Assess capability to treat. Identify the practical design and operational constraints.
- For the candidate technologies:
  - estimate removal efficiencies for the four pollutants
  - estimate capital and O&M cost for a 5 million gallon per day (MGD) system
  - examine costs for a 0.5 MGD and then a 25 MGD treatment system
- Qualitatively identify any adverse collateral environmental impacts. Incremental electrical energy use, GHG emissions, residuals management and disposal, air emissions.

**Table 5: Summary of Arsenic Removal Technologies<sup>1</sup>**

| Technology             | Advantages   | Disadvantages  |
|------------------------|--|--|
| Coagulation/filtration | <ul style="list-style-type: none"> <li>• Simple, proven technology</li> <li>• Widely accepted</li> <li>• Moderate operator training</li> </ul>             | <ul style="list-style-type: none"> <li>• pH sensitive</li> <li>• Potential disposal issues of backwash waste</li> <li>• As<sup>+3</sup> and As<sup>+5</sup> must be fully oxidized</li> </ul>  |
| Lime softening         | <ul style="list-style-type: none"> <li>• High level arsenic treatment</li> <li>• Simple operation change for existing lime softening facilities</li> </ul> | <ul style="list-style-type: none"> <li>• pH sensitive (requires post treatment adjustment)</li> <li>• Requires filtration</li> <li>• Significant sludge operation</li> </ul>   |
| Adsorptive media       | <ul style="list-style-type: none"> <li>• High As<sup>+5</sup> selectivity</li> <li>• Effectively treats water with high TDS</li> </ul>                     | <ul style="list-style-type: none"> <li>• Highly pH sensitive</li> <li>• Hazardous chemical use in media regeneration</li> <li>• High concentration SeO<sub>4</sub><sup>-2</sup>, F<sup>-</sup>, Cl<sup>-</sup>, and SO<sub>4</sub><sup>-2</sup> may limit arsenic removal</li> </ul> |
| Ion exchange           | <ul style="list-style-type: none"> <li>• Low contact times</li> <li>• Removal of multiple anions, including arsenic, chromium, and uranium</li> </ul>      | <ul style="list-style-type: none"> <li>• Requires removal of iron, manganese, sulfides, etc. to prevent fouling</li> <li>• Brine waste disposal</li> </ul>   |
| Membrane filtration    | <ul style="list-style-type: none"> <li>• High arsenic removal efficiency</li> <li>• Removal of multiple contaminants</li> </ul>                            | <ul style="list-style-type: none"> <li>• Reject water disposal</li> <li>• Poor production efficiency</li> <li>• Requires pretreatment</li> </ul>   |

<sup>1</sup>Adapted from WesTech

# Evaluation of Toxics Treatment Effectiveness and Costs

## Treatment Processes

- Desktop Analysis
  - HDR Experience
  - Technical Literature Review
- Treatment Process Effectiveness for Toxics Removal
  - Existing Secondary Treatment
  - Additional Removals in Advanced Treatment
    - Limited Information Available on Full Scale Performance for Toxics
- Two Advanced Treatment Process Trains Selected
  1. Micro Filtration Membrane followed by Reverse Osmosis (MF/RO)
  2. Micro Filtration Membrane followed by Granular Activated Carbon Adsorption (MF/GAC)

## Cost Analysis


- Preliminary Cost Opinions
  - Association for the Advancement of Cost Engineering (AACE International)
    - Recommended Practice No. 17R-97 Cost Estimate Classification System
      - Class 4 Estimate
        - » 5% to 10% Project Definition
        - » Expected Accuracy: -30% to +50%

# Microfiltration Membranes

**Spokane County Regional Water Reclamation Facility MBR**



**LOTT Martin Way Reclamation Plant MBR**



# Microfiltration Followed by Either....

## Reverse Osmosis (RO)



Scottsdale, AZ Water Campus

## Granular Activated Carbon (GAC)



Potable Water Treatment

# Key Findings on Technologies

- Technology/Performance capability
  - PCBs: no demonstration of ability to achieve the Oregon criterion
  - Arsenic: no demonstration of ability to achieve a 0.018 µg/L criterion
  - Mercury: possibly able to achieve Oregon-like criterion
  - B(a)P: Insufficient information to make judgment
- Expect many site-specific challenges with retrofit of advanced treatment technology onto existing facilities
  - Disposal of Reverse Osmosis brine (1-10% of influent flow)
  - Land requirements for advanced treatment technologies

# Treatment Technology Costs

- 5 Million Gallon per Day (mgd) Facility


| Alternative   | Total Construction Cost, 2013 dollars (\$ Million) | O&M Net Present Value, 2013 dollars (\$ Million) *** | Total Net Present Value, 2013 dollars (\$ Million) | NPV Unit Cost, 2013 dollars (\$/gpd) |
|---|--|--|--|--------------------------------------|
| Baseline (Conventional Secondary Treatment) *       | 59 - 127   | 5 - 11   | 65 - 138   | 13 - 28                              |
| Incremental Increase to Advanced Treatment - MF/RO  | 48 - 104   | 26 - 56  | 75 - 160   | 15 - 32                              |
| Advanced Treatment - MF/RO **                       | 108 - 231  | 31 - 67  | 139 - 298  | 28 - 60                              |
| Incremental Increase to Advanced Treatment - MF/GAC | 71 - 153   | 45 - 97  | 117 - 250  | 23 - 50                              |
| Advanced Treatment - MF/GAC                         | 131 - 280  | 50 - 108   | 181 - 388  | 36 - 78                              |

- Basis: Net Present Value, 25 year project life. “Baseline” costs do not include probable needed secondary treatment system upgrades for existing facilities.

# Collateral Impacts of Advanced Treatment

- Larger Plant Site Physical Space Requirements for Additional Unit Processes
- High Energy Consumption
  - Additional Pumping, Mixing, etc
- Increased Chemical Use
- Increased Residual Solids Production
- Increased Truck Hauling
- RO Brine Disposal
- Carbon Regeneration

## Increased Greenhouse Gas Emissions



# Key Outcomes

- The traditional process to derive human health-based water quality standards yields very stringent numeric criteria (Oregon 2011). Certain pollutants are ubiquitous and seem to pose exceptional regulatory challenges (PCBs, mercury, arsenic and benzo(a)pyrene).
  - Assumed Washington would have arsenic criterion of 0.018 µg/L
- There are no “proven” advanced treatment technology options with demonstrated capability of achieving Oregon-like water quality criteria for PCBs and arsenic, and perhaps not for mercury.
- Advanced treatment technologies are very expensive to construct and operate. There would be formidable site-specific challenges in retrofitting existing secondary treatment systems.
- There are significant adverse collateral environmental impacts associated with these technologies.
- The full report can be accessed at: <http://www.awb.org/hdrtechreport/>

# Questions

Tom Dupuis

[tom.dupuis@hdrinc.com](mailto:tom.dupuis@hdrinc.com)

208.387.7069

Dave Clark

[dclark@hdrinc.com](mailto:dclark@hdrinc.com)

208.387.7025