



Institute for Healthcare
Facilities Management

Name: _____

Certification Number: _____

Out n' About

Nurse Call Pull Cord – NFPA 99 CH 7 & Local/State Codes


7.3.3.1.6.1 – Provided for toilet, bath, shower, or sitz bath and accessible by patient lying on the floor. Note – Distance within 4" or 6" of floor without touching is most common recommendation. Verify with local/state policy.

7.3.3.1.10 – ..geriatric, Alzheimer, and other dementia units call cord SHALL not be longer than 6".

Make sure cords are free from obstructions, knotting, or wrapped around anything.

Ensure there is a device at end to assist in pulling.

Survey a unit, floor, or building.

☐

Completed With No
Findings (0.5 CEC)

☐

Completed With
Findings (1 CEC)

Findings:

Managers Signature: _____

For more information on submitting your CEC's,
go to IHFEA.com (PLACEHOLDER
INFORMATION)