



Knock Out, Drag Out Fight: Centrifuge vs. Belt Filter Press - Title for Best Dewatering Technology to Squeeze Biosolids at William. E. Dunn Water Reclamation Facility

NC One Water Conference

November 4, 2024

Shyam Sivaprasad, *Process Engineer*

Manuel Moncholi, *Senior Process Engineer*



Content

- WEDWRF Background
- Pilot Testing Objective
- Pilot Testing Overview
- Pilot Testing Results
- Life Cycle Cost Analysis
- Conclusions
- Questions and Discussion




WEDWRF Facility Background


Facility Background

William E Dunn Water Reclamation Facility,
Pinellas County, Florida

Parameter	Value
Annual Average Daily Flow	6.5 MGD
Ultimate Design Capacity	9.0 MGD
Biological Nutrient Removal Process	5-stage-Bardenpho
Existing Solids Thickening	Rotary Drum Thickeners (RDT)
Existing Solids Dewatering	Belt Filter Press
Existing Solids Disposal	Offsite thermal drying



Facility Overview



Pilot Testing Objective


Pilot Testing Objectives

- Evaluate the performance of BFP and Centrifuge to dewater TWAS and WAS by bypassing the RDT
- Optimize the polymer dosage range to maximize cake solids and solids capture
- Perform life cycle cost analysis for full scale dewatering improvement alternatives




Pilot Testing Overview

Pilot equipment Set-up




Pilot Evaluation PFD

Option 1 – Dewatering Waste Activated Sludge



Pilot Evaluation PFD

Option 2 – Dewatering Thickened Waste Activated Sludge




Pilot Testing Summary

Alfa Laval – 3-Belt Filter Press Summary

Pilot Testing Period - April 18 – April 27, 2023

Parameter	WAS (~0.5% TS)	TWAS (~2.5% TS)
Testing Period	April 18 – 20, 2023	April 25 – 27, 2023
Hydraulic Loading (gpm)	170 – 225	50 – 73
Solids Loading (lb/hr)	436 – 942	600 – 1,000
Polymer	Clarifloc SE – 1692 (Existing plant polymer) and Clarifloc C-6266	Clarifloc C-6266
Polymer Dosage (lb/ton)	10 – 17	7 - 12




Alfa Laval AS-H Belt Press KPZ (1.3 m)



Pilot Testing Summary

Alfa Laval – 3-Belt Filter Press



(a) TWAS gravity belt (b) Dewatering (c) Dewatered TWAS cake solids (d) Combined filtrate and wash water flowing into sump.



Pilot Testing Summary

Andritz – Centrifuge Summary

Pilot Testing Period - May 8 – May 17, 2023

Parameter	WAS (~0.5% TS)	TWAS (~2.5% TS)
Testing Period	May 8 – 10, 2023	May 15 – 17, 2023
Hydraulic Loading (gpm)	70 - 130	25 – 65
Solids Loading (lb/hr)	210 - 390	280 – 950
Polymer	Clarifloc C-6262, Clarifloc C-6266, and Zetag 8840 FS	Clarifloc C-6262, Clarifloc C-6266, and Zetag 8840 FS
Polymer Dosage (lb/ton)	15 – 64	19 – 45




ANDRITZ Decanter High Performance Centrifuge (D4L)



Pilot Testing Summary

Andritz – Centrifuge



Centrate from (a) WAS and (b) TWAS



Dewatered cake from (a) WAS and (b) TWAS



Pilot Testing Summary

Alfa Laval – Centrifuge Summary

Pilot Testing Period May 23 – June 6, 2023

Parameter	WAS (~0.5% TS)	TWAS (~2.5% TS)
Testing Period	May 23 – 25, 2023	June 5 – 6, 2023
Hydraulic Loading (gpm)	100 - 140	100
Solids Loading (lb/hr)	235 - 350	1,400 – 1,500
Polymer	Clarifloc C-6266	Clarifloc C-6266
Polymer Dosage (lb/ton)	13 - 36	28 – 32



Alfa Laval ALSYS G3-75 Centrifuge



Pilot Testing Summary

Alfa Laval – Centrifuge



(a)



(b)



(c)


(a) Alfa Laval ALSYS G3-75 Centrifuge, (b) Centrate, and (c) Dewatered Cake



Pilot Testing Results

Pilot Testing Results

WAS and TWAS Feed TSS Characteristics




Manufacturer	Equipment	Average WAS Feed TSS (%)	Average TWAS Feed TSS (%)
Alfa Laval	Belt Filter Press	0.52	1.88
Andritz	Centrifuge	0.57	2.13
Alfa Laval	Centrifuge	0.50	2.43




Pilot Testing Results

Polymer Dosage and Cake Solids Comparison for WAS



Pilot Testing Results

Polymer Dosage and Cake Solids Comparison for TWAS




Manufacturer	Equipment	Average TWAS Cake Solids (%TS)	Average TWAS Polymer Dosage Active (lb/Ton)
● Alfa Laval	Belt Filter Press	17.0	9.7
◆ Andritz	Centrifuge	20.9	28.6
■ Alfa Laval	Centrifuge	20.0	28.7



Pilot Testing Results

Solids Capture and Sample Number for WAS




● Alfa Laval BFP
 ◆ Andritz Centrifuge
 ■ Alfa Laval Centrifuge

Manufacturer	Equipment	Average Solids Capture for WAS
● Alfa Laval	Belt Filter Press	98.7%
◆ Andritz	Centrifuge	90.5%
■ Alfa Laval	Centrifuge	97.2%



Pilot Testing Results

Solids Capture and Sample Number for TWAS



Manufacturer	Equipment	Average Solids Capture for TWAS
● Alfa Laval	Belt Filter Press	98.4%
◆ Andritz	Centrifuge	96.2%
■ Alfa Laval	Centrifuge	98.5%



Pilot Testing Results Summary

- Both belt filter press and centrifuge can exceed the 17.5% cake solids requirement
- Both centrifuge and belt filter press can attain $\geq 95\%$ solids capture

Belt Filter Press: Recommended Performance Criteria

3-Belt Filter Press		
Parameter/Feed	WAS	TWAS
Cake Solids (%TS)	18%	17.5%
Polymer Dosage (Active) (lb/Ton)	15	12
Solids Capture (%)	95%	95%

Centrifuge: Recommended Performance Criteria

Centrifuge		
Parameter/Feed	WAS	TWAS
Cake Solids (%TS)	22%	21%
Polymer Dosage (Active) (lb/Ton)	35	30
Solids Capture (%)	95%	95%



Solids Projection

Solids Loading Projections Summary

Based on Master Plan concentrations, flow projections and historical influent data/concentrations

Parameter	Value	WAS Solids Production Ratios				Estimated WAS Production Range (lbs./day)	Estimated WAS Processing Capacity Range (lbs./op hr)
		Avg WAS (lbs./day) / Influent (MGD)	Avg WAS (lbs./day)/ Influent TSS (lbs./day)	Avg WAS (lbs./day) / Influent BOD (lbs./day)	Avg WAS (lbs./day) / Influent TSS + Influent BOD (lbs./day)		
2040 Avg Day Flow	5.83 mgd	1,713	1.27	1.07	0.58	9,990 – 11,321	1,093 – 1,238
Permitted Flow	9.0 mgd					15,421 – 17,477	1,686 – 1,912

Solids production ratio based on influent TSS determined to be *most conservative* using *permitted flow*.

Adjusted for operating schedule: 4 days/ week @ 16 hrs/day

Used 2,000 lbs./hr. capacity for equipment sizing

- 2.5% TS for **TWAS** operation scheme: 153 gpm rounded to 160 gpm
- 0.5% TS for **WAS** operation scheme: 766 gpm, rounded to 800 gpm



Life Cycle Cost Analysis

Class 5 Opinion of Probable Construction Costs (OPCC)

- Alternative 1 – Dewatering TWAS using BFP (in existing building)
- Alternative 2 – Dewatering TWAS using Centrifuge (in existing building)
- Alternative 3 – Dewatering WAS using BFP (in modified existing building)
- Alternative 4 – Dewatering WAS using Centrifuge (in new dewatering building)

Alternative	Class V OPCC
1- Dewatering TWAS using BFP's	\$4,776,733
2- Dewatering TWAS using Centrifuges	\$4,575,055
3- Dewatering WAS using BFP's	\$13,987,930
4- Dewatering WAS using Centrifuges	\$18,584,483

Accuracy range for Class 5 OPCC ranges from -20 to +30%




Annual O&M Costs

- Power unit cost - \$0.095/kWh
- Labor cost – \$20/hour per operator
- Neat Emulsion Polymer cost - \$12.9/gal
- Maintenance – 2% /year of equipment cost
- Potable Water Cost - \$5.26 /1,000 gal
- Dewatering System Maintenance Labor- 2% of Equipment Operation Time
- Routine Centrifuge Labor Time – 10 hr/day
- Routine BFP Labor Time – 16 hr/day
- Operational costs (power and polymer) for thickening system (Alternatives 1 and 2)
- Biosolids Hauling Cost - \$15 / wet ton of solids¹.
- Natural Gas Drying Cost - \$0.865/ Therm²



Annual O&M Costs

Annual O&M Costs



Net Present Value Analysis

$$NPV = \text{Capital Cost} + \text{Annual O\&M Cost} \frac{(1 + r)^{n-1}}{r * (1 + r)^n}$$

Time Period (n) – 25-years

Annual Discount Rate (r) – 3 %

Alternative	Net Present Value (\$)
1- Dewatering of TWAS using BFP's	\$21,193,000
2- Dewatering of TWAS using Centrifuges	\$24,333,000
3- Dewatering of WAS using BFP's	\$32,040,000
4- Dewatering of WAS using Centrifuges	\$41,686,000



Conclusions

Conclusions

- Both Centrifuge and BFP can dewater the sludge to $\geq 17.5\%$ TS
- Both Centrifuge and BFP have solids capture of $\geq 95\%$
- Polymer consumption for centrifuge was at least twice as much as BFP for both WAS and TWAS
- Continuing the use of existing thickening operation is more economical than dewatering WAS
- Alternative 1 (Dewatering TWAS with BFP) offers overall long- term cost savings and BFP is used in existing plant operations
- Based on discussions with County and overall considerations of facility implementation, capital costs, operating costs, and NPV evaluation, Alternative 1 was selected



Acknowledgements

Acknowledgements

- Jeovanni Ayala – Lugo – Principal Process Engineer, Stantec
- Simon Meikle – Senior Project Manager, Stantec
- Kenneth Broome – Client Service Manager, Stantec
- Thomas Menke – Engineering Section Manager, WEDWRF
- Craig Osanski – Engineering, WEDWRF
- Heather Canham – Chief Wastewater Plant Operator, WEDWRDF





Questions and Discussion




Shyam Sivaprasad, MS, EIT
Shyam.Sivaprasad@stantec.com

Manny Moncholi, PhD, PE
Manuel.Moncholi@stantec.com

Appendix

Alternative 3 –WAS using BFP Layout


- Additional volume required for WAS storage (1.22 MG vs 0.44 MG existing)
 - Two new tanks to accommodate the total volume
 - Required new mixing/aeration system for the additional volume
 - Tanks located north of clarifiers
- Larger hydraulic requirement for dewatering equipment
 - Will require larger dewatering feed pumps
 - New dewatering feed pipes due to tank location
- Upgrade from dry polymer to emulsion polymer
 - Building extension allows for construction without affecting current operation
- Requires 3 installed BFP units (2 duty + 1 standby)
- Existing Dewatering Building expansion (to south) to accommodate extra unit
- Modification of conveyor system
- Utilize existing truck scale
- Requires temporary mobile dewatering unit during construction



Existing Dewatering building, 3rd floor Conceptual Layout, BFP using WAS

Alternative 4 –WAS using Centrifuges, New Building Layout

- Additional WAS storage volume (1.26 MG vs 0.44 MG existing)
 - Assumed two new tanks to accommodate the total volume
 - New mixing/aeration system for the additional volume
- New Dewatering Building due to structural modifications to existing building
- New building and WAS storage both proposed north of clarifiers
- Larger hydraulic requirement for dewatering equipment
 - Will require larger dewatering feed pumps
 - New dewatering feed pipes due to tank location
- Requires 3 installed units (2 duty + 1 standby)
- Upgrade from dry polymer to emulsion polymer
- New truck scale
- Does not require temporary mobile dewatering unit during construction




NEW Dewatering building, 2nd floor Conceptual Layout, Centrifuge using WAS




Annual O&M Costs Distribution

Annual O&M Costs


ALT 1 TWAS WITH BFP - \$0.94M




ALT 2 TWAS WITH CENTRIFUGE - \$1.13M



ALT 3 WAS WITH BFP - \$1.04M



ALT 4 WAS WITH CENTRIFUGE-



- Emulsion Polymer, \$/yr
- Biosolids Hauling Cost, \$/yr
- Natural Gas Drying Cost, \$/yr
- Power, \$/yr
- Emulsion Polymer Potable Water, \$/yr
- Labor, \$/yr
- Maintenance, \$/yr