

Clarification Request

Request From: "Carl Neilson" <technicaladvisor@bacnetinternational.org>

References: 135.1.2013 7.3.2.X37.1.6

Stage: Request, Listed, Analysis, Resolved

Actions Necessitated: Checklist/Test Plan Change, BTL Specified Tests Change,

SSPC Interpretation Required, Implementation Guidelines Change,

Date of BTL-WG Response: 19-December-2019

All Actions Necessitated have been Completed

Background:

Problem:

The Accumulator object's Out_Of_Service test tests the Pulse_Rate property in step 6:

```
6. REPEAT X = (all values meeting the functional range requirements of 7.2.1) DO {  
    WRITE Pulse_Rate = X  
    VERIFY Pulse_Rate = X  
}
```

The Pulse_Rate property is optional so the test cannot be applied as written.

Question:

Should step 6 be skipped when the object does not support the Pulse_Rate property.

Response:

YES