



WDMA TECHNICAL INTERPRETATION 97-02

Approved: 5/07

DATE OF INQUIRY: May 4, 1978

PERTINENT SPECIFICATION: ANSI/AAMA/NWDA 101/LS.2-97, “Voluntary Specifications for Aluminum, Vinyl (PVC) and Wood Windows and Glass Doors”

SECTION(S) IN QUESTION: Guide Buttons

INTERPRETATION REQUESTED: A manufacturer has his unit tested with a certain number and location of guide buttons. On smaller units manufactured can the number of guides be reduced, and if so, what is the rule to be followed?

INTERPRETATION MADE: All manufactured units shall have guide buttons that:

1. Do not exceed the distance from the end of the extrusion, sash or panel from that of the tested unit.
2. Spacing does not exceed that of the tested unit.

REVIEWED/ APPROVED BY:

COMMITTEE	COMMENTS / ACTION	STATUS
JDMG		
WDMA	Approved by WDMA Exterior Product Standards Committee	Approved - 5/15/07
AAMA	Originally Approved by AAMA Technical Policy Planning Committee as AAMA Technical Interpretation #17.	Approved – 11/85 Ed. Revised – 2/94, 1/97